


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

DAC

1 Location of well:	County Sheridan	Township name Valley	Fraction SW$\frac{1}{4}$NE$\frac{1}{4}$SE$\frac{1}{4}$	Section number 2	Town number 8	Range number 26W				
Distance and direction from nearest town or city: 2 1/2 miles North; 1 mile West Street address of well location if in city:				3 Owner of well: Bill Schieferecke Address: Studley, Kansas						
Locate with "X" in section below: N 		Sketch map:		4 Well depth: 184 ft. Date of completion 1/15/76 Well diameter 30 in.						
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary						
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>						
				7 Casing: Material Steel Height: above 4 ft. below 114 ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. Weight 31.6 lbs./ft. to 14 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
				8 Screen: Manufacturer Brown ; 10' Cook Type Regular Dia. 16" Slot/gauze 10% Length 60' Set between 114 ft. and 174 ft. 184 Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material 1/4 X 5/8; 50% #1						
				9 Static water level: 96 ft. below land surface Date 1/16/76						
				10 Pumping level below land surfaces: 175 ft. after 2 hrs. pumping 618 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 618 g.p.m.						
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____						
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade 12						
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 10 ft.						
				14 Nearest source of possible contamination: ft. 2600 Direction North Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway 2-13-76 Model number 7624 HP 50 Volts ____ Length of drop pipe 170 ft. capacity ____ g.m.p. Type: 10 stage 10" DOH bowl <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
				16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well and Pump 245 Business name License No. ____ Address PO Box 852 Colby, Ks. Signed Sally Berry Date 3/22/76 Authorized representative		

8 26w & 26wESE