

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

HOXIE ZSW

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

AAD

1 Location of well:	County SHERIDAN	Township name KENNETH	Fraction SE SW-NE-NE	Section number 21	Town number 8	Range number 28 W
Distance and direction from nearest town or city: South Edge of HOXIE, KS.			3 Owner of well: Cooper GRAM			
Street address of well location if in city:			Address: HOXIE Ks.			
Locate with "X" in section below:		Sketch map:		4 Well depth: 76 ft. Date of completion: 2/21/77 Well diameter 9" in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
2		Type and color of material		From	To	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
		sandy clay		0	10	7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. Weight 200 lbs./ft. 5 in. to 76 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		river mud		10	33	8 Screen: Manufacturer Jess Lowell Type PVC Dia. 5 Slot/gauze 7/8 Length 8' Set between 58 ft. and 76 ft.
		7 sand		33	41	Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8" - 1/4"
		in gravel		41	43	9 Static water level: 21 ft. below land surface Date 2/21/77
		sandy clay		43	47	10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 30 g.p.m. plus
		gravel		47	50	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
		sandy clay		50	65	12 Well head completion: 12 <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
		gravel		65	75	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 4 ft. to 12 ft.
		Ochre		75	76	14 Nearest source of possible contamination: ft. 300 Direction NORTH Type CREEK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		BROCK 75'				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Grundfos Model number 2927 HP 1 Volts 220 Length of drop pipe 68 ft. capacity 23 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation		2665 (TOPO)		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STANCKHOFF SONS License No. 298 Business name Address GRINNELL Ks Signed R. Stanckhoff Date 4/23/77 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

28 W 21 SW NE NE