USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215 Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

Job #225-77-C-2-8-29

	County	Fraction		Section number		Township number	Range number		
1. Location of well:	Sheridan	NW 1/4 NW 1/4 SW 1/4		2		т 8 ѕ	R 29	<b>½</b> ∕W	
2. Distance and direction from nearest town or city: Hoxie; 2 N; 3. Owner of well: John Wade									
4 3/4 W Street address of well location if in city:  City, stat					ore, zip code: Hoxie, Kansas				
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia. 30 in. Completion date 10-8-7/ Well depth 265 ft.			0-8-77	
N T I I						Well depth 200 ft.  7. Cable tool Rotary	Driven Duc		
						Hollow rod Jetted Bored XXXReverse rotary			
						8. Use: Domestic Public supply Industry  XX Irrigation Air conditioning Stock			
						Lawn Oil field water Other			
SW SE						9. Casing: Material <u>Steel</u> Height: Above or <b>XXX</b> Threaded Welded X Surface in.			
S						RMPPVCWeight188_lbs./ft.			
I → Mile → I				From	То	Dia. 16in, to 195 ft. depth Wall Thickness: inches or Dia. in, to ft. depth gage No. #7			
5. Type and color of material				1100	10	10. Screen: Manufacturer's name Brown			
Top Soil				0	120	Type Bridge Dia. 16"  Slot/gauze 10% Length 60  Set between 195 ft. and 255 ft. 10 Cook ft. and 265 ft. Gravel pack? X Size range of material 4 x 5/8			
Large Medium Gravel				120	123				
Sandy Clay				123	133				
						11. Static water level: mo./day/yr.			
Small Med. Gravelw/fine sand&Sandy Clay Streaks					145				
Sandy Clay				145	151	12. Pumping level below land surfaces: 256 ft. after 2 hrs. pumping 1471 g.p.m.			
Large Medium Gravel				151	167	ft. after hrs. pumping g.p.m. Estimated maximum yield 1471 g.p.m.			
Sandy Clay, Sandstone Streaks				167	191	13. Water sample submitted: mo./day/yr.  Yes X No Date			
Med. Gravel, Mostly white				191	197	14. Well head completion:			
Sandstone Sandy Clay				197	220	Pitless adapter 12 Inches above grade 15. Well grouted? $X$			
Fine Sand Streaks of Sandy Clay, Fine Sand				220	226	With: Neat cement X Bentonite X Concrete Depth: From 0 ft. to 10 ft.			
Med. Gravel, Mostly White				226	258	16. Nearest source of possible contamination: ft. 1000 Direction E Type House Well disinfected upon completion? Yes X No  17. Pump: Not installed Manufacturer's name Floway			
Ochre, Shale				258	265				
BROOK 75%					eccession mass				
						Model number 85427	_ HP <u>125</u> ∨		
				-		Length of drop pipe 250 ft. capacityg.p.m. Type: 6 Stage 12 DOH			
						Submersible Jet	X Turbii	ne rocating	
(Use a second sheet if needed)						Centrifugal	Other	1 / 4	
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report			
Topography:					is true to the best of my knowledge and belief.				
Hill						Western Well &	n Well & Pump 245 ox 852, Colby, KS 67701		
Slope X_Upland						1 11 11 11 11 11 11 11 11 11 11 11 11 1			
Valley						Signed Authorized representative Date			