

MENCC SW

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

BDD

1. Location of well:		County Sheridan	Fraction SE 1/4 SE 1/4 NW 1/4	Section number #10	Township number T 8 S R 30	Range number EAW
2. Distance and direction from nearest town or city: 1 1/2 miles West & 1 mile North Street address of well location if in city:			3. Owner of well: Kenneth Frahm R.R. or street: 18 Cottonwood Drive City, state, zip code: Colby, Kansas			
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile 1 Mile			6. Bore hole dia. 28 in. Completion date 9-30-75 Well depth 276 ft.			
5. Type and color of material			7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary			
Clay			8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other			
Medium to coarse sand & gravel			9. Casing: Material steel Height Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC ___ Weight .188 lbs./ft. Dia. 16 in. to 186 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth Gage No. #7			
Sandy clay			10. Screen: Manufacturer's name W. A. Brown Type perforated Dia. 16" Slot gauze 1/8 Length 60' Set between 186 ft. and 266 ft. 10' of cook ft. and 276 ft. Gravel pack? yes Size range of material 1/4 x 5/8			
Medium to coarse sand & gravel			11. Static water level: mo./day/yr. 135 ft. below land surface Date 10-01-75			
Clay			12. Pumping level below land surfaces: 160 ft. after 3 hrs. pumping 1900 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 2500 g.p.m.			
Medium to coarse sand & clay			13. Water sample submitted: mo./day/yr. ___ Yes <input checked="" type="checkbox"/> No Date			
Sandstone			14. Well head completion: ___ Pitless adapter 12 Inches above grade			
Medium to coarse sand & gravel & clay streaks			15. Well grouted? yes With: ___ Neat cement <input checked="" type="checkbox"/> Bentonite ___ Concrete Depth: From 0 ft. to 10 ft.			
Coarse sand & gravel			16. Nearest source of possible contamination: ft. 5300 Direction East Type Farm Well disinfected upon completion? ___ Yes <input checked="" type="checkbox"/> No			
Clay & cemented streaks			17. Pump: ___ Not installed Manufacturer's name Byron Jackson Model number 12 G.H. HP 150 Volts 460 Length of drop pipe 250' ft. capacity 1100 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other			
Coarse sand & gravel & cemented streaks			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245 Business name License No. Address P.O. Box 852, Colby, Ks. Signed Roy E. Danvers Date Nov 1/4 Authorized representative			
Clay & sand streaks			18. Elevation: 2940 (TOPO)			
Medium to coarse sand & clay streaks			19. Remarks: BROCK 275			
Coarse sand & gravel			Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley			
Gravel			275 275			
Shale			(Use a second sheet if needed)			

T  
8  
3  
0  
W  
1  
0  
SE  
SE  
NW  
1/4  
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5