

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

MENLO SE

WATER WELL RECORD
KSA 82a-1201-1215

CCA CAC

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Sheridan	Fraction NE 1/4 SW 1/4 SW 1/4	Section number #12	Township number T 8 S R 30	Range number 30	SE/W
2. Distance and direction from nearest town or city: From Menlo, Ks., 5 miles East & 1 1/2 mile North Street address of well location if in city:				3. Owner of well: Mr. Paul Steele R.R. or street: City, state, zip code: Colby, Kansas			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map:		6. Bore hole dia. 28 in. Completion date _____ Well depth 274 ft. 10-3-75	
5. Type and color of material				From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay				0	80	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Coarse sand & gravel				80	90	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight .188 lbs./ft. Dia. 16 in. to 184 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. #7	
Clay				90	100	10. Screen: Manufacturer's name W. A. Brown Type regular Dia. 16" Slot/gauze 10 % Length 80' Set between 184' ft. and 264' ft. 10' of cook ft. and 274' ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/4 x 5/8	
Sandy clay				100	115	11. Static water level: _____ mo./day/yr. 132 ft. below land surface Date 10-4-75	
Medium to coarse sand				115	120	12. Pumping level below land surfaces: 188 ft. after 2 hrs. pumping 2084 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 2084 g.p.m.	
Clay				120	150	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
Coarse sand & gravel				150	168	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
Clay				168	170	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Coarse sand & gravel				170	180	16. Nearest source of possible contamination: ft. 4000' Direction N.W. Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Sand stone				180	182	17. Pump: _____ Not installed Manufacturer's name Byron Jackson Model number _____ HP 100 Volts 480 Length of drop pipe 250' ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Coarse sand & gravel				182	198	18. Elevation: _____ 19. Remarks: 2923 (TOPO) 2920	
Clay & cement streaks				198	235	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump Inc., 245 Business name _____ License No. _____ Address P.O. Box 852, Colby, Ks. Signed Roy Sena Date Nov 17-75 Authorized representative	
Fine to medium sand				235	238	21. Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
Clay				238	246	22. Forward the white, blue and pink copies to the Department of Health and Environment	
Coarse sand & gravel				246	251	Form WWC-5	
Clay				251	253	M1-1023	
Coarse sand & gravel				253	260		
Gravel				260	274		
Shale (Use a second sheet if needed)				274	---		

8300
 12
 1/4 NE
 1/4 SW
 Sec