


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Township - Menlo

1. Location of well:		County Thomas	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 4	Township number T 8 S R 31	Range number +EAW
2. Distance and direction from nearest town or city: From Colby, Ks. 3/4 miles South; 13 miles East Street address of well location if in city:				3. Owner of well: Phil Ljungdahl R.R. or street: City, state, zip code: Dodge City, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 1/21/76 Well depth 268 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	60	9. Casing: Material Steel Height: Above 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia. 16 in. to 158 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.188		
Coarse sand & gravel		60	74	10. Screen: Manufacturer's name Brown 10" Cook		
Clay		74	92	Type Regular Dia. 16" Slot/gauze 10% Length 100' Set between 158 ft. and 258 ft. 258 ft. and 268 ft.		
Coarse sand & gravel		92	100	Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8; 50% #1		
Medium to coarse sand & clay streaks		100	121	11. Static water level: 121 ft. below land surface Date 1/22/76		
Clay		121	133	12. Pumping level below land surfaces: 175 ft. after 2 hrs. pumping 1557 g.p.m. 168 ft. after 1 hr. pumping 1557 g.p.m. Estimated maximum yield 1557 g.p.m.		
Medium sand		133	137	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
Clay		137	151	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Coarse sand & gravel		151	162	15. Well grouted? <input checked="" type="checkbox"/> Clay With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Clay & sand streaks		162	168	16. Nearest source of possible contamination: ft. 300 Direction SW Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Coarse sand & gravel		168	178	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway 3-18-76 Model number 7607-1 HP 100 Volts Length of drop pipe 260 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> 5 stage 12" DOH bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay & layers of sand		178	186			
Medium to coarse sand		186	202			
Cement		202	209			
Clay		209	215			
Coarse sand & gravel		215	217			
Ochre		217	233			
Medium to coarse sand		233	241			
Clay		241	252			
Coarse sand & gravel		252	255			
Ochre & Shale		255	268			
BRICK 268'		268	280			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well and Pump 245 Business name Box 852 Colby, Ks. License No. Address Sally Berry Date 3/22/76 Signed Sally Berry Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5