


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DCD

1. Location of well:		County Thomas	Fraction SE 1/4 SW 1/4 SE 1/4	Section number 16	Township number T 8 S	Range number R 31 E
2. Distance and direction from nearest town or city: From Menlo, Ks. 3 miles West Street address of well location if in city:				3. Owner of well: Carl Stevens R.R. or street: City, state, zip code: Menlo, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 				6. Bore hole dia. 30 in. Completion date _____ Well depth 218 ft. 4-15-76		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above or below _____ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 128 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 0.188		
				10. Screen: Manufacturer's name Brown 10" Cook Type Perforated Dia. 16" Slot/gauze 10% Length 80" Set between 128 ft. and 208 ft. 208 ft. and 218 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 X 5/8 50% #1		
				11. Static water level: _____ mo./day/yr. 94 ft. below land surface Date 4-22-76		
				12. Pumping level below land surfaces: 190 ft. after 2 hrs. pumping 1450 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1450 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> Clay With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 5300 Direction South Type Farm Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
				17. Pump: _____ Not installed Manufacturer's name Floway Model number 7643 HP 150 Volts _____ Length of drop pipe 200 ft. capacity 1200 g.p.m. Type: 7 stage 12" DOH bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks: BROCK 315'		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump Inc. 245 Business name _____ License No. _____ Address PO Box 852 Colby, Ks. Signed Darryl Berry Date 5/1/77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5