


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Thomas	Fraction NE 1/4 NE 1/4 SW 1/4	Section number # 5	Township number T 8 S R 32 E/W	Range number
2. Distance and direction from nearest town or city: 6 miles East, 1/2 mile South & 1/2 mile East Street address of well location if in city:		3. Owner of well: Vernon Flanagan R.R. or street: 1126 Terrace Drive City, state, zip code: Colby, Kansas 67701			
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 28 in. Completion date 9-19-75 Well depth 250 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay & sand streaks		0	100	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Medium to coarse sand & gravel		100	114	9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight .188 lbs./ft. Dia. 16 in. to 180 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7	
Clay & sand streaks		114	123	10. Screen: Manufacturer's name W. A. Brown Type regular Dia. 16" Slot/gauze 1/8 Length 60' Set between 180 ft. and 240 ft. 10' of cook ft. and 250 ft. Gravel pack? yes Size range of material 1/4 x 5/8	
Medium to coarse sand & clay streaks		123	136	11. Static water level: <input type="checkbox"/> mo./day/yr. 100 ft. below land surface Date 9-20-75	
Clay & sand stone streaks		136	160	12. Pumping level below land surfaces: 160 ft. after 2 hrs. pumping 2150 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 2150 g.p.m.	
Medium to coarse sand & gravel & sand stone & Clay streaks		160	177	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
Sand stone		177	179	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Medium to coarse sand		179	183	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Clay & sand stone streaks		183	186	16. Nearest source of possible contamination: ft. 2600' Direction East Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Medium to coarse sand & gravel		186	226	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number <input type="checkbox"/> HP 80 Volts <input type="checkbox"/> Length of drop pipe 250 ft. capacity 550 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Medium to coarse sand & sand stone & clay streak		226	232	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245 Business name License No. <input type="checkbox"/> Address P.O. Box 852, Colby, Ks. Signed Roy F. Senning Date Nov 1975 Authorized representative	
Medium to coarse sand & gravel		232	238		
Ochre & Shale		249	250		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 3040 (TOPO) BROCK 249' (Use a second sheet if needed)			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5