WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	Caunty	Feeinter 1/4 1/4 SW 1/4		Section number		Township number	Range number	7
1. Lacation of well:	Thomas					T 8 s	R 32 XE/W	
2. Distance and direction from nearest town or city: From Colby, Ks.; 3. Own 7½ miles east; 2-3/4 miles From Colby, Ks.; R.R. or Street address of well location if in city:				treet:		Schielke Farms Colby, Kansas		
4. Locate with "X" in section below: Sketch map:				tate, zip code:		6. Bore hole dia. <u>36</u> in. Completion date Well depth <u>244</u> ft. <u>9/4/76</u>		
NW NE						7Cable toolRotaryDrivenDugHollow rodJettedBoredXReverse rotary 8. Use:DomesticPublic supplyIndustryX IrrigationAir conditioningStockLawnOil field waterOther		
9M SE I I I I I I I I I I I I I I I I I I						9. Casing: Materia CONCT Control of the Shift: Above by below Threoded Welded Surfacein. RMP PVC Weight 188 lbs./ft.		
_	ile ————					Dia 22''in. to 184 ft. dept		1
5. Type and color af material				From	То	Dia in. to ft. depth gage No		
Clay)	35	Kelly Type concrete Dia, 22"		
Gravel			3	35	40	Slot/gauze 184 Length 60 Set between ft. and 244 ft.		
Gravel & streaks of clay				ŧ0	60	ft. andft. Gravel pack? X Size range of material X 5/8		
Clay & gravel			6	50	80	11. Static water level:		
Gravel & streaks of clay			8	30	95	12. Pumping level below land surfaces: 18 7ft. after 2 hrs. pumping 1935 g.p.m.		1
Clay				95	100	ft. after hrs. pumping g.p.m.		
Clay & gravel streaks				100	120	13. Water sample submitted: mo./day/yr.		
Fine sand, clay & streaks of sand stone				120	140	Yes X No Date 14. Well head completion:		
Fine sand & clay				140	160	Pitless adapter	2" Inches above grade	-
Coarse sand w/ medium gravel & streaks of clay				160	180	With: Neat cementx Bentonite _x Concreve Depth: From O _ ft . to 10 _ ft .		
Clay w/ streaks of medium gravel & sandstone				180	195	16. Negrest source of possible contamination: House ft. 3/4 m Direction N-NW Type		
Medium gravel				195	220	Well disinfected upon complet	ion? Yes <u>X</u> No	4
Fine to coarse sand			2	220	228		Not installed way	7
Fine sand & clay			2	228	240	Model number <u>056157</u> Length of drop pipe <u>230</u>	HP 100 Volts 480 to capacity 650 g.p.m.	
Medium gravel			2	240	243	Type: Submersible	X Turbine	
Shale	(Use a second st	neet if needed)	2	243	244	Jet Centrifugal	Reciprocating	200
18. Elevation:	19. Remarks:	ICK 243'				20. Water well contractor's co This well was drilled under my	jurisdiction and this report	
Topography:						is true to the best of my knowl Western Well &	Pump, Inc. 245	174
Hill Slope						Address P.O. Box 85	2, Colby, Ks.	1/4
XUpland Valley		with the file file and the second				Signed Signed representation of the signed s	sentative pate Lgul	X :
orward the white, blu	e and pink copies to the Department	of Health and Environment					Form WWC-5	