


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Thomas	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 32	Township number T 8 S R 32	Range number W
2. Distance and direction from nearest town or city: 7 East; 5 1/2 South; 1/8 West Street address of well location if in city:			3. Owner of well: Henry Siebert R.R. or street: City, state, zip code: Colby, KS		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W 1 Mile E S</div> 			6. Bore hole dia. 30 in. Completion date 12-6-76 Well depth 166 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight .188 lbs./ft. Dia. 12 in. to 96 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7		
			10. Screen: Manufacturer's name Brown Type Regular Dia. 12" Slot/gauze 10% Length 60' Set between 96 ft. and 156 ft. 10' John. 156 ft. and 166 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 2x5/8 30% #1		
Top Soil			0	100	11. Static water level: 108 ft. below land surface Date 12-8-76
Sandy Clay			100	103	12. Pumping level below land surfaces: 156 ft. after 2 hrs. pumping 259 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 259 g.p.m.
Med. Coarse Sand			103	113	13. Water sample submitted: 10' John. 156 ft. and 166 ft. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
Sandy Clay			113	118	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
Med. Coarse Sand			118	127	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 10 ft.
Sandstone			127	129	16. Nearest source of possible contamination: ft. 1000 Direction NE Type Farm Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Sandy Clay			129	135	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name HPC Model number 6HHO-05A HP 15 Volts Length of drop pipe 164 ft. capacity 240 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Med. Sand			135	143	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852, Colby, KS 67701 Signed Sally Berry Date 11/6/77 Authorized representative
Sandy Clay			143	149	
Med. Sand			149	154	
Med. Coarse Sand			154	162	
Ochre, Shale					
BROCK 1 1/2'					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5