


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

GEM SW

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NW 1/4 SW 1/4 NE 1/4	Section number 22	Township number T 9 S	Range number R 32 E/W
2. Distance and direction from nearest town or city: 33 E. of Colby Street address of well location if in city:				3. Owner of well: Iland G. Wilson R.R. or street: Rte. 2 Box 10 City, state, zip code: Colby, Kansas 67701		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 8 in. Completion date 12/20/76 Well depth 170 ft.		
5. Type and color of material		From	To	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top Soil		0	10	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sand		10	49	9. Casing: Material 1 1/2" Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 1/2 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 1 1/2 in. to 170 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 032 320 MAC		
Sand Clay		49	102	10. Screen: Manufacturer's name I and L Type RMP Dia. 1 1/2" Length 20' 20' MAC Slot/gouze 1/32" Set between 150 ft. and 170 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8"		
Sand and Clay Strips		102	112	11. Static water level: 130 ft. below land surface Date 12/20/76 mo./day/yr.		
Sand and Sand Rock		112	121	12. Pumping level below land surfaces: ft. after NA hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Clay and Sand		121	167	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
Shale		167	170	14. Well head completion: no <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
BROCK 167'				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Nept cement <input type="checkbox"/> Bestonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 18 ft.		
				16. Nearest source of possible contamination: ft. 20 Direction east Type barn yard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks: 3012 (TOP)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bartell Drilling 139 Business name License No. Address Winona, Kansas 67764 Signed [Signature] Date 6-7-77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5