


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction Ne 1/4 NW 1/4	Section number 4	Township number T 8 S	Range number R 33 E/W
2. Distance and direction from nearest town or city: 1 1/4 E. 1/4 S. Colby, Ks.			3. Owner of well: Hi Plains Coop R.R. or street: 405 E. 4th City, state, zip code: Colby, Kansas 67701			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 3-22-75 Well depth 263 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	138	9. Casing: Material Plst Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> gl Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 2 1/2 in. to 2 1/2 ft. depth Wall Thickness: inches or Dia. 5 in. to 2 1/2 ft. depth gage No. 250		
fine sand med gravel sandy clay		138	150	10. Screen: Manufacturer's name Peerless Plastics Type PVC Dia. 5" Slot/gauze .06 Length 10' Set between 253 ft. and 263 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4 X 1/8		
fine sand sandy clay		150	156	11. Static water level: <input type="checkbox"/> mo./day/yr. 126 ft. below land surface Date 3-22-75		
fine sand med gravel		156	159	12. Pumping level below land surfaces: AIR ft. after <input type="checkbox"/> hrs. pumping AIR g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 100 g.p.m.		
fine sand sandy clay		159	192	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
fine sand sand stone		192	194	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
fine sand med gravel		194	250	15. Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 20 ft.		
fine sand ochre shale		260	263	16. Nearest source of possible contamination: none ft. Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number ut-50/12 HP 5 Volts 230 Length of drop pipe 231 ft. capacity 70 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Blue Jay Drilling Inc. 214 Business name Box 503 Colby, Ks 67701 Address Box 503 Colby, Ks 67701 Signed Rich Hall Date 7/24/80 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5