


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

ACA
TWP: Morgan

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 28	Township number T 8 S R 33 E/W	Range number
2. Distance and direction from nearest town or city: From Colby, Ks 5 miles South, 2 1/2 miles East - 1/2 mile North				3. Owner of well: Harold Hills R.R. or street: RFD #2 City, state, zip code: Colby, Kansas 67701		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 4/6/76 Well depth 218 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil- sandy clay & medium gravel		0	105	9. Casing: Material Steel Height: Above or below surface 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 7 gauge Dia. 16 in. to 148 ft. depth Wall Thickness: inches or Dia. 16 in. to 218 ft. depth gage No. 188		
Sandy clay & fine sand & med. gravel		10	130	10. Screen: Manufacturer's name Brown 10 Cook Type Perforated Dia. 16 " Slot/gauze 10% Length 60 ' Set between 148 ft. and 208 ft. 208 ft. and 218 ft.		
Sandy clay		130	132	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 5/8 10% #1		
Medium gravel		132	137	11. Static water level: 118 ft. below land surface Date 4-9-76		
Sandy clay & sandstone streaks		137	157	12. Pumping level below land surfaces: 190 ft. after 2 hrs. pumping 460 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 460 g.p.m.		
Fine sand & medium gravel snug		157	160	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
Fine sand & medium gravel		160	164	14. Well head completion: Pitless adapter 12 inches above grade		
Fine sand & medium gravel & streaks of clay		164	179	15. Well grouted? <input checked="" type="checkbox"/> Clay With: Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
Sandy clay		179	182	16. Nearest source of possible contamination: ft. 4000 Direction SE Type Feedlot Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Sandy clay		182	191	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number 7640 HP 50 Volts Length of drop pipe 200 ft. capacity 460 g.p.m. Type: 10 stage 10" DOL bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Mostly fine sand & medium gravel traces		191	203	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address PO Box 852 Colby, Ks Signed Daily Barry Date 5-6-76 Authorized representative		
Medium gravel & fine sand		203	210			
Ochre & shale		210	220			
BROCK 220'		220	230			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5