

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


COLBY

WATER WELL RECORD
KSA 82a-1201-1215

ABE

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Thomas</u>	Township name <u>NE-NW-NW</u>	Fraction <u>2</u>	Section number <u>8</u>	Town number <u>5</u>	Range number <u>34</u>
Distance and direction from nearest town or city: <u>3 miles west of Colby, KS</u>			3 Owner of well: <u>Dean Barker</u> <u>545 W. 3</u> <u>Colby, Kansas 67701</u>			
Street address of well location if in city:			Address:			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map: <u>see enclosed sketch</u>			4 Well depth: <u>197</u> ft. Date of completion <u>11-8-76</u> Well diameter <u>6</u> in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Top Soil, Clay, Silty, Clay Brown			0	100	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
Sandy Clay, Streak Sand Stone, Brown			100	102	7 Casing: Material <u>PVC</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>5</u> in. Diam. <u>5</u> in. to <u>5</u> ft. depth Drive shoe: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Fine Sand Med. Gravel Streak Sandy Clay			102	120	8 Screen: Manufacturer <u>Ac6 Plastics</u> Type <u>slot</u> Dia. <u>5"</u> Slot/gauze <u>20'</u> Length <u>20'</u> Set between <u>177</u> ft. and <u>197</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4"</u>	
Sandy Clay, Brown			120	128	9 Static water level: <u>170</u> ft. below land surface Date <u>9-12-76</u>	
Fine Sand, Medl Gravel, Brown			128	131	10 Pumping level below land surfaces: <u>174</u> ft. after <u>6</u> hrs. pumping <u>36</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>36-45</u> g.p.m.	
Med. Gravel, Sandy Clay, Brown			131	140	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
Fine Sand Streak Sandy Clay Sand Stone			140	150	12 Well head completion: <u>white water runs</u> <input type="checkbox"/> PTFE adapter <input type="checkbox"/> Inches above grade	
Fine Sand, Med. Gravel, Brown			150	156	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> <u> </u> Depth: From <u>0</u> ft. to <u>10</u> ft.	
Sandy Clay, Sand Stone, Brown			156	162	14 Nearest source of possible contamination: ft. <u>150</u> Direction <u>west</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Fine Sand, Med. Gravel, Sand Stone			162	183	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Gould</u> Model number <u>3564</u> HP <u>5 HP</u> Volts <u>230</u> Length of drop pipe <u>170</u> ft. capacity <u>35</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Fine Sand-Med. Gravel- Streak Sandy Clay			183	190	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Red Tiger Irrigation</u> <u>125</u> Business name License No. Address <u>Box 534 Colby, KS</u> Signed <u>Dean Barker</u> Date <u>12-8-76</u> Authorized representative	
Fine Sand, Med. Gravel, Brown			190	196		
Sandy Clay, Trace Ochre			196	200		
Ochre - yellow, Shale - blue			200	210		
BROCK 200'						
(use o second sheet if needed)						
16 Remarks: elevation <u>3169 (TOPO)</u>						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5