USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

Forward the white, blue and pink copies to the Department of Health and Environment

COUBY SE

WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and **Environment-Division of Environment** (Water well Contractors)

Job #159-77-A-16-8-34 Topeka, Kansas 66620 County Section number Township number Range number 1. Location of well: 1/4 SE 1/4 NE 1/4 Thomas 16 X Co1by; 2½ S; 3. Owner of well: Elmer Schielke 2. Distance and direction from neorest town or city: $3\frac{1}{4}$ W Street address of well location if in city: City, state, zip code: Colby, Kansas 6. Bore hole dia. 30 in. Completion date 5-4-77 4. Locate with "X" in section below: Sketch map: Well depth $\underline{231}_{ft}$. Ν 7. __ Cable tool __ Rotary __ Driven __ Dug Hollow rod ___ Jetted ____ Bored ___X Reverse rotary LX 8. Use: __ Domestic __ Public supply __ Industry Mile w X Irrigation __ Air conditioning __ Stock ___ Lawn ___ Oil field water ___ Other SW -9. Casing: Material Steel Height: Above or KKK Threaded _____ Welded X Surface ____12 ____Weight __.188__lbs./ft RMP_____ PVC ____ Dia. 16in. to 161. depth Wall Thickness: inches or 1 Mile Dia. ____in. to _____ ft. depth gage No. _#7 5. Type and color of material From To 10. Screen: Monufacturer's name _ Brown 0 Clay, Coarse Sand 130 Type Bridge Slot/gauze __10\) 60 Coarse Sand, Med. Gravel 130 155 Set between 161 10' Cook Cook X _ft, and _ Fine Sand, Clay 155 180 Gravel pack? ___ Size range of materia 4 X 11. Static water level: 180 190 Coarse Sand 158 ft. below land surface Date 2-14-7712. Pumping level below land surfaces: 228 ft. after 2 hrs. pumping Clay, Sand Streaks 190 200 _____ ft. after ___ _ hrs. pumping Sandstone, Clay 200 213 Estimated maximum yield 1800 g.p.m. Sandstone, Clay 213 214 13. Water sample submitted: mo./day/yr Yes X No Date Coarse Sand, Med. Gravel, Clay Streaks 214 231 14. Well head completion: Pitless adapter Inches above grade 15. Well grouted? X With: Neat cement X Bentonite X Concrete Depth: From ______ ft. to _____ ft. 16. Nearest source of possible contamination: ft. 3/4 Moirection West Type Farmstead Well disinfected upon completion? _____ Yes ____ No _ Not installed Manufacturer's name F10way

Model number 85332 HP 75 Volts 480

Length of drop pipe 210 ft. capacity 700g.p.m. Type: 11 STage 10" DOH ____ Submersible XX Turbine ____ Jet Reciprocating (Use a second sheet if needed) _ Centrifugal Other 18. Elevation: 19. Remarks 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Topography: Western Well & Pump __ Hill Business name Address Box 852 Colby KS __ Slope X__ Upland Valley Author