

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


COLBY SW

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ADC
SDB ML SE-SE

1 Location of well:	County Thomas	Township name Morgan	Fraction N.W. 1/4	Center of	Section number #19	Town number T 8 S	Range number R 34 W
Distance and direction from nearest town or city: & 2 1/2 mile South of Levant, 1 1/2 mile East Street address of well location if in city:				3 Owner of well: Ernest Schielke Colby, Kansas 67701			
Locate with "X" in section below: 				Sketch map: correction			
2 Type and color of material				From	To	4 Well depth: 232 ft. Date of completion 2-20-75 Well diameter 36 in.	
Soil				0	5	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay & sand streaks				5	143	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
Fine to coarse sand & gravel & clay				143	158	7 Casing: Material concrete Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 17 in. to 232 ft. depth Weight 3" thick Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Fine to coarse sand & gravel				158	176	8 Screen: Manufacturer Kelly Well Co. Type concrete Dia. 17" Slot/gauze 1/4 Length 6" Set between 162 ft. and 232 ft.	
Sandy clay				176	191	9 Static water level: 135 ft. below land surface Date 2-20-75	
Sandy clay with layers of fine to coarse sand & gravel				191	203	10 Pumping level below land surfaces: 225 ft. after 2 hrs. pumping 505 g.p.m. Estimated maximum yield 505 g.p.m.	
Fine to coarse sand & gravel				203	220	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
Sandy clay				220	222	12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
Fine to coarse sand & gravel				222	230	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 0 ft. to 10 ft.	
Ochre				230	232	14 Nearest source of possible contamination: 1 1/2 mile Direction N.E. Type feedlot Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
(use a second sheet if needed)						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Byron Jackson Model number H8052 HP 75 Volts Length of drop pipe 220 ft. capacity 450 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation 3257 (TUPD) 3254				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & pump inc. Business name License No. 243 Address P.O. Box 852 Signed Roy F. Jensen Date 3-14-75 Authorized representative			