


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Thomas</b>	Fraction <b>SW 1/4 SW 1/4 SE 1/4</b>	Section number <b>19</b>	Township number <b>T 8 S R 34</b>	Range number <b>EW</b>
2. Distance and direction from nearest town or city: <b>Colby, Kansas</b> <b>3mi South; 5 1/2 mi. West</b> Street address of well location if in city:				3. Owner of well: <b>Wendy Frahm</b> R.R. or street: City, state, zip code: <b>Colby, Kansas 67701</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>30</b> in. Completion date _____ Well depth <b>270</b> ft. <b>12-21-78</b>		
				7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: _____ Domestic _____ Public supply _____ Industry <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other		
Clay & Top Soil		0	45	9. Casing: Material <b>Steel</b> Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP _____ PVC _____ Weight <b>34.17</b> lbs./ft. Dia. <b>16</b> in. to <b>270</b> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. <b>204</b>		
Medium Sand		45	75	10. Screen: Manufacturer's name <b>Cook</b> Type <b>Wire Wrapped</b> Dia. <b>16"</b> Slot/gauze <b>100</b> Length <b>10</b> Set between <b>260</b> ft. and <b>270</b> ft. <b>Brown Bridge</b> ft. and <b>260</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>30# 1-70 1/4 x 5/8</b>		
Clay		75	81	11. Static water level: _____ mo./day/yr. <b>170</b> ft. below land surface Date <b>12-22-78</b>		
Medium Gravel		81	100	12. Pumping level below land surfaces: <b>205</b> ft. after <b>2</b> hrs. pumping <b>1683</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>2000</b> g.p.m.		
Fine Sand & Clay Layers		100	124	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
Sandy Clay & Sandstone		124	140	14. Well head completion: _____ Pitless adapter <b>12</b> Inches above grade		
Fine Sand & Medium Sand		140	156	15. Well grouted? <b>yes</b> With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
Sandy Clay		156	160	16. Nearest source of possible contamination: ft. <b>8000</b> Direction <b>East</b> Type <b>Farmstead</b> Well disinfected upon completion? _____ Yes _____ No		
Sandy Clay & Sandstone ( Loose )		160	175	17. Pump: _____ Not installed. Manufacturer's name <b>Floway</b> Model number <b>10DOH</b> HP <b>75</b> Volts _____ Length of drop pipe <b>265</b> ft. capacity <b>600</b> g.p.m. Type: _____ Submersible <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other		
Medium Gravel		175	180	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Western Well &amp; Pump Inc. 245</b> Business name _____ License No. _____ Address <b>Box 852 Colby, Kansas 67701</b> Signed <b>R.D. Coulton</b> Date <b>3-9-79</b> Authorized representative		
Fine Sand & Clay Layers		180	192			
Fine Sand & Medium Gravel		192	222			
Sandstone & Fine Sand		222	230			
Medium Gravel & Gravel		230	242			
Clay		242	245			
Medium Gravel		245	270			
Ochre & Shale (Use a second sheet if needed)		270	280			
18. Elevation:		19. Remarks: <b>BROCK 270'</b>				
Topography: _____ Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5