


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

AAC

1. Location of well:	County Thomas	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 21	Township number T 8 S R 34	Range number 1/W
2. Distance and direction from nearest town or city: 3 1/4 South, 3 1/4 West of Colby, KS Street address of well location if in city:		3. Owner of well: Elmer Schielke R.R. or street: City, state, zip code: Colby, KS 67701			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 36 in. Completion date _____ Well depth 254 ft. 12-29-77	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay, Sand Streaks		0	140	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay Sand Streaked		140	162	9. Casing: Material Concrete Above or below Threading <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 18 in. to 184 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 4	
Fine to Coarse Sand		162	195	10. Screen: Manufacturer's name Kelly Well Screen Type Concrete Dia. 12 " Slot/gauze _____ Length 20' Set between 184 ft. and 254 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 5/8	
Clay		195	211	11. Static water level: _____ mo./day/yr. 175 ft. below land surface Date 12-30-77	
Fine to Coarse Sand, Clay Streaks		211	232	12. Pumping level below land surfaces: 199 ft. after 3/4 hrs. pumping 1,005 p.m. 210 ft. after 1 1/6 hrs. pumping 1,250 p.m. Estimated maximum yield 1,200 g.p.m.	
Clay		232	235	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Fine to Coarse Sand		235	251	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Ochre & Shale		251	254	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
BROCK 251'				16. Nearest source of possible contamination: ft. 4,000 Direction West Type Farmstead Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
(Use a second sheet if needed)				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number 2SR10DOH HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name Box 852, Colby, KS License No. _____ Address _____ Signed John P. [Signature] Date 6-3-78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5