


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County	Fraction	Section number	Township number	Range number
		Thomas	C 1/4 SW 1/4	26	T 8 S R	34 E 2W
2. Distance and direction from nearest town or city: From Colby 3 1/2 South; 1 3/4 West, 1/4 North Street address of well location if in city:			3. Owner of well: Paul Steele R.R. or street: City, state, zip code: Colby, Kansas			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		6. Bore hole dia. 30 in. Completion date 9-8-76 Well depth 262 ft.	
5. Type and color of material			From	To	7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay, Sandy Clay			0	105	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other	
Med. Coa. Sand, Gravel			105	116	9. Casing: Material Steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC ___ Weight .188 lbs./ft. Dia. 16 in. to 172 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. #7	
Clay			116	122	10. Screen: Manufacturer's name Brown Type Regular Dia. 16" Slot/gauze 10% Length 80' Set between 172 ft. and 252 ft. 10' Cook 252 ft. and 262 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 5/8 30% #1	
Sand, Gravel			122	127	11. Static water level: ___ mo./day/yr. 154 ft. below land surface Date 9-10-76	
Clay, Sand Streaks			127	165	12. Pumping level below land surfaces: 256 ft. after 2 hrs. pumping 1280 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 1280 g.p.m.	
Coarse Sand, Gravel			165	186	13. Water sample submitted: ___ mo./day/yr. ___ Yes <input checked="" type="checkbox"/> No Date	
Clay			186	197	14. Well head completion: ___ Pitless adapter 12 inches above grade	
Sand, Gravel			197	201	15. Well grouted? <input checked="" type="checkbox"/> Clay With: ___ Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Coa. Sand, GRavel, Clay Streaks			201	214	16. Nearest source of possible contamination: ft. 4000 Direction E Type House Well disinfected upon completion? ___ Yes <input checked="" type="checkbox"/> No	
Coa. Sand, Gravel			214	230	17. Pump: ___ Not installed Manufacturer's name Floway Model number 056207 HP 100 Volts 480 Length of drop pipe 240 ft. capacity 599 g.p.m. Type: 10 Stage ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other	
Clay			230	232	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852, Colby, KS Signed Sally Berry Date 10-29-76 Authorized representative	
Sand Stone Streaks			232	233		
Sandx, Gravel			233	257		
Ochre, Shale			257	262		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: BROCK 259'				
Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5