

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


COLBY SE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

#1 Job #187-77-A-28-8-34

AAC ACA

1. Location of well:		County Thomas	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 28	Township number T 8 S R 34 E/W	Range number
2. Distance and direction from nearest town or city: Colby; 4 S; 3 1/4 W; 1/4 S			3. Owner of well: Ken Frahm			
Street address of well location if in city:			R.R. or street: Colby, Kansas			
City, state, zip code:						
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 5-18-77 Well depth 272 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input checked="" type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry XX Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	65	9. Casing: Material Steel Height: Above ground 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 16 in. to 202 ft. depth Wall thickness 1/8 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 77		
Sand, Gravel		65	85	10. Screen: Manufacturer's name Brown Type Bridge Dia. 16" Slot/gauze 10% Length 60" Set between 202 ft. and 262 ft. 10 Johnson ft. and 272 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 x 5/8		
Sandy Clay, Cemented		85	130	11. Static water level: 178 ft. below land surface Date 6-8-77 mo./day/yr.		
Clay		130	163	12. Pumping level below land surfaces: 200 ft. after 2 hrs. pumping 1902 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1902 g.p.m.		
Sand		163	167	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
Clay, Cemented		167	175	14. Well head completion: 12 inches above grade Pitless adapter <input type="checkbox"/>		
Coarse Sand, Gravel		175	228	15. Well grouted? <input checked="" type="checkbox"/> X With: Neat cement <input checked="" type="checkbox"/> X Bentonite <input checked="" type="checkbox"/> X Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
Clay		228	231	16. Nearest source of possible contamination: ft. 3300 Direction NE Type House Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Coarse Sand, Gravel		231	262	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number 85369 HP 100 Volts 480 Length of drop pipe 250 ft. capacity 600 g.p.m. Type: 11 Stage 10" DOH Bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> X Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Ochre, Shale		262	268	18. Elevation:		
		268	272	19. Remarks: 3255 (TPO) 3257		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name Box 852 Colby, KS License No. 67701 Address Colby, KS Signed Dale Berry Date 6/21/77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5