

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

COLBY SW

WATER WELL RECORD
KSA 82a-29-1215

CAA

BIRD

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction NE 1/4 NE 1/4 SW 1/4	Section number #31	Township number T 8 S R 34	Range number 4W
2. Distance and direction from nearest town or city: 5 miles South & 5 1/2 miles West Street address of well location if in city:			3. Owner of well: Kenneth Frahm R.R. or street: 18 cottonwood Drive City, state, zip code: Colby, Ks. 67701			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 			6. Bore hole dia. 28 in. Completion date 10-8-75 Well depth 260 ft.			
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay			0	55	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Medium to coarse sand & gravel			55	71	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight .188 lbs./ft. Dia. 16 in. to 190 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7	
Clay			71	75	10. Screen: Manufacturer's name W. A. Brown Type perforated Dia. 16" Slot/gauge 1/8 Length 60' Set between 190 ft. and 250 ft. 10' of cook ft. and 260 ft. Gravel pack? yes Size range of material 1/2 x 5/8	
Medium to coarse sand & gravel			75	86	11. Static water level: 162 ft. below land surface Date 10-10-75	
Clay & sand streaks			86	93	12. Pumping level below land surfaces: 221 ft. after 2 hrs. pumping 1975 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 2000 g.p.m.	
Medium to coarse sand & gravel & clay streak			93	110	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
Coarse sand & gravel			110	137	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Clay			137	156	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Coarse sand & gravel			156	176	16. Nearest source of possible contamination: ft. 2 mile Direction E-SE Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Clay			176	179	17. Pump: Not installed Manufacturer's name Byron Jackson Model number <input type="checkbox"/> HP 100 Volts 460 Length of drop pipe 250 ft. capacity 550 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Medium to coarse sand & gravel			179	193	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump Inc., 245 Business name License No. Address P.O. Box 852, Colby, Ks/ Signed Roy E. Jensen Date Nov 18 1975 Authorized representative	
Medium to coarse sand & clay streaks			193	212		
Coarse sand & gravel			212	257		
Shale			257	260		
BROCK 257'						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: 3271 (TUPO)				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5