


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BREWSTER SE

LEA AISC

1. Location of well:		County Thomas	Fraction NW 1/4 Ne 1/4 SE 1/4	Section number #22	Township number T 8 S R 36	Range number 28/W
2. Distance and direction from nearest town or city: 3 miles East, 1 1/2 mile South & 1/8 mile West				3. Owner of well: Lou Palmgren City, state, zip code: Brewster, Ks.		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 11-1-75 Well depth 187 ft.		
				7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary		
5. Type and color of material		From To		8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other		
Clay		0 56		9. Casing: Material steel Height: Above or below Threaded Welded X Surface 12 in. RMP PVC Weight .188 lbs./ft. Dia. 16 in. to 117 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. #7		
Medium to coarse sand & gravel		56 64		10. Screen: Manufacturer's name W. A. Brown Type regular Dia. 16" Slot/gauze 10% Length 60" Set between 117 ft. and 177 ft. 10' of cook ft. and 187 ft. Gravel pack YES Size range of material 1/4 x 5/8		
Clay		64 79		11. Static water level: mo./day/yr. 115' ft. below land surface Date 11-3-75		
Coarse sand & gravel		79 89		12. Pumping level below land surfaces: 171 ft. after 2 hrs. pumping 294' g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 300 g.p.m.		
Clay		89 93		13. Water sample submitted: mo./day/yr. Yes X No Date		
Coarse sand & gravel		106 115		14. Well head completion: Pitless adapter 12 inches above grade		
Clay		115 124		15. Well grouted? yes With: Neat cement X Bentonite Concrete Depth: From 0 ft. to 10 ft.		
Medium to coarse sand		124 136		16. Nearest source of possible contamination: ft. 1300 Direction East Type Farm Well disinfected upon completion? Yes X No		
Clay & sand streaks		136 150		17. Pump: X Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: Submersible Turbine Jet Reciprocating Centrifugal Other		
Clay & cemented sand & stones		150 164		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245 Business name P.O. Box 852, Colby, Ks. Address Signed Roy Jensen Date 11-1-75 Authorized representative		
Medium to coarse sand & clay & sand stone stk.		164 171				
Medium gravel		171 179				
Ochre & Shale		179 187				
BROCK 179'						
(Use a second sheet if needed)						
18. Elevation: Topography: Hill Slope X Upland Valley		19. Remarks: 3350 (TOD) 3380				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5