


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>SHERMAN</u>	Fraction <u>SE 1/4 SE 1/4 SW 1/4</u>	Section number <u>16</u>	Township number <u>T 8 S</u>	Range number <u>R 39 E</u>
2. Distance and direction from nearest town or city: <u>Goodland</u> Street address of well location if in city: <u>1 E</u>			3. Owner of well: <u>WEARY & CASSITY</u> R.R. or street: <u>640 CRESTVIEW</u> City, state, zip code: <u>JUNCTION CITY KANSAS 66441</u>			
4. Locate with "X" in section below:			Sketch map:			
						
5. Type and color of material			From	To	6. Bore hole dia. <u>3 1/2</u> in. Completion date <u>12-28-77</u> Well depth <u>274</u> ft.	
<u>Top Soil</u>			<u>0</u>	<u>3</u>	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
<u>Clay TRACC GRUVCL</u>			<u>3</u>	<u>7.5</u>	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<u>SANDY CLAY, SANDSTONE</u>			<u>7.5</u>	<u>100</u>	9. Casing: Material <u>SRCL</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36</u> lbs./ft. Dia <u>1 1/2</u> in. to <u>1 3/4</u> ft. depth Wall Thickness: inches or Dia. <u>1 1/2</u> in. to <u>1 3/4</u> ft. depth gage No. <u>219</u>	
<u>M GRUVCL, SANDSTONE</u>			<u>100</u>	<u>153</u>	10. Screen: Manufacturer's name <u>W. H. BROWN</u> Type <u>SAUCER</u> Dia. <u>1 1/2</u> Slot/gauze <u>1/8</u> <u>219</u> Length <u>96</u> Set between <u>184</u> ft. and <u>274</u> ft. Gravel pack? <u>YES</u> Size range of material <u>1/4 to 3/8</u>	
<u>SANDY CLAY, SANDSTONE</u>			<u>153</u>	<u>161</u>	11. Static water level: <u>155</u> ft. below land surface Date <u>9-8-76</u>	
<u>M GRUVCL, SANDY CLAY</u>			<u>161</u>	<u>172</u>	12. Pumping level below land surfaces: <u>252</u> ft. after <u>8</u> hrs. pumping <u>530</u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>530</u> g.p.m.	
<u>M GRUVCL</u>			<u>172</u>	<u>184</u>	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
<u>M GRUVCL, SANDY CLAY</u>			<u>184</u>	<u>225</u>	14. Well head completion: <input type="checkbox"/> Pitless adapter <u> </u> inches above grade	
<u>M GRUVCL</u>			<u>225</u>	<u>230</u>	15. Well grouted? <u>YES</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>1</u> ft. to <u>10</u> ft.	
<u>M GRUVCL, SANDY CLAY</u>			<u>230</u>	<u>242</u>	16. Nearest source of possible contamination: <u>Feed</u> fr. <u>2600</u> Direction <u>WEST</u> Type <u>LOT</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<u>FINE SAND, SANDSTONE</u>			<u>242</u>	<u>247</u>	17. Pump: <u>Not installed</u> Manufacturer's name <u>Western Land Rollers</u> Model number <u>6M</u> HP <u>30</u> Volts <u>460</u> Length of drop pipe <u>260</u> ft. capacity <u>600</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
<u>FINE SAND, SANDY CLAY</u>			<u>247</u>	<u>254</u>		
<u>M GRUVCL</u>			<u>254</u>	<u>270</u>		
<u>CHRC</u>			<u>270</u>	<u>274</u>		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>3645 (TOD)</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>SAH Dwyer & Co. Inc.</u> License No. <u>166</u> Address <u>Goodland Kansas</u> Signed <u>Bill Clifford</u> Date <u>1-3-77</u> Authorized representative		