

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CBA

1. Location of well: County SHERMAN Fraction NE NW SW Section number 1 Township number 8 Range number 40	
2. Distance and direction from nearest town or city: 2 W 3 N 1/4 3. Owner of well: John Herberich	
Street address of well location if in city: GOODLAND R.R. or street: GOODLAND, KANSAS City, state, zip code: 62235	
4. Locate with "X" in section below: Sketch map:	
6. Bore hole dia. 3 3/4 in. Completion date 7-12-76 Well depth 300 ft.	
7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 8 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 32 lbs./ft. Dia. 8 in. to 300 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188	
10. Screen: Manufacturer's name W.A. Brown Type Mittsalt Dia. 16 Slot/gauze 1/8 Length 20 Set between 260 ft. and 300 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2	
11. Static water level: <input type="checkbox"/> mo./day/yr. 167 ft. below land surface Date 7-6-76	
12. Pumping level below land surfaces: 268 ft. after 8 hrs. pumping 500 g.p.m. 280 ft. after 16 hrs. pumping 667 g.p.m. Estimated maximum yield 607 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8 ft. to 10 ft.	
16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction NE Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WESTERNLAND PUMP Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe 290 ft. capacity 667 g.p.m. Type: Gas motor <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation:	19. Remarks:
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	BROCK 301'
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Faust Supply, Inc 144 Business name License No. Address Box 338 Goodland Kan Signed Ralph Egan mgr Date 10-23-76 Authorized representative	

8
 40
 NE NW SW
 1/4 1/4 1/4