


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ARB

1. Location of well:		County SHERMAN	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 26	Township number T 8	Range number S 40 W 10
2. Distance and direction from nearest town or city: Street address of well location if in city: Goodland 1 1/2 W				3. Owner of well: Roy NELSON R.R. or street: 1119 CENTER City, state, zip code: Goodland KANSAS 67735		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 8 in. Completion date _____ Well depth 290 ft. 6-2-79		
5. Type and color of material				From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Top Soil				0	4	8. Use: <input checked="" type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay				4	41	9. Casing: Material WARK Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> X Height _____ lbs./ft. Dia. 4 in. to 257 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 237
GRAVEL				41	50	10. Screen: Manufacturer's name _____ PEERLESS Type LOUYER Dia. 5' Slot/gauze 1/8 .258 Length 36 Set between 257 ft. and 290 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/8
Sandy Clay, Sandstone				50	102	11. Static water level: _____ mo./day/yr. 162 ft. below land surface Date 6-1-79
M Gravel				102	109	12. Pumping level below land surfaces: 190 ft. after 3 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.
Sandy Clay				109	145	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
M Gravel				145	156	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
Sandy Clay, Sandstone				156	176	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.
M Gravel				176	195	16. Nearest source of possible contamination: cesspool ft. 435 Direction West Type _____ <input checked="" type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Sandy Clay, Sandstone				195	222	17. Pump: _____ Not installed Manufacturer's name Red Jacket Model number 11CC HP 1/2 Volts 230 Length of drop pipe 232 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Hard Sandstone				222	230	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. SAH Dullberg Co Inc 146 Business name _____ License No. _____ Address Goodland Kansas Signed Bill Clifford Date 6-7-79 Authorized representative
Gravel Sandstone				230	246	
M Gravel				246	252	
DCRC (Use a second sheet if needed)				252	286	
18. Elevation:		19. Remarks: BROCK 286'				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T-8 40 W 26 NW 10 NE