

RULETONE 35

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

CAC

1. Location of well:		County <b>SHERMAN</b>	Fraction <b>SW 1/4 NE 1/4 SW 1/4</b>	Section number <b>13</b>	Township number T <b>8</b> S	Range number R <b>41</b> E <b>(M)</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
2. Distance and direction from nearest town or city: <b>5 SW 1/4 N</b> Street address of well location if in city: <b>OF GOODLAND.</b>			3. Owner of well: <b>DWIGHT BRINEY</b> R.R. or street: City, state, zip code: <b>GOODLAND, KANS.</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>14</b> in. Completion date <b>1-14-73</b> Well depth <b>282</b> ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	3	9. Casing: Material <b>STEEL</b> Height: <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>8</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>35</b> lbs./ft. Dia. <b>16</b> in. to <b>38 1/2</b> in. depth, Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth, gage No. <b>1.88</b>		
Sandstone Gravel & Clay		3	140	10. Screens: Manufacturer's name <b>W. H. BRAWLEY</b> <b>ENTERPRISE</b> Type <b>MILL SALT</b> Dia. <b>16"</b> Slot/gauze <b>1/8</b> Length <b>20'</b> Set between <b>120</b> ft. and <b>282</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>7/8 to 1/2</b>		
Gravel		140	148	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>140</b> ft. below land surface Date <b>11-12-73</b>		
Clay Gravel & Sandstone		148	161	12. Pumping level below land surfaces: <b>165</b> ft. after <b>60</b> hrs. pumping <b>100</b> g.p.m. <b>230</b> ft. after <b>16</b> hrs. pumping <b>845</b> g.p.m. Estimated maximum yield <b>845</b> g.p.m.		
Gravel		161	163	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date		
Clay Sandstone & Gravel		163	195	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade		
Gravel		195	198	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>Surface</b> to <b>10</b> ft. <b>6 ft. (low)</b>		
Sandstone & Clay		198	212	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Fine Sand		212	220	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sandstone		220	222	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Foust Supply Co Inc</b> <b>144</b> Business name License No. Address <b>Box 338</b> Signed <b>Ralph Sherman mgr.</b> Date <b>1-20-73</b> Authorized representative		
Gravel		222	229			
Sandstone & Clay		229	237			
Sand		237	242			
Sandy clay		242	251			
Gravel		251	270			
Shale		270				
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<b>3746 (TOPO)</b> <b>Concrete will be run by Foust Supply Co Inc.</b> <b>Ralph Sherman mgr.</b>				

T 8  
R 41 E  
S 13 SW NE SW  
1/4 1/4 1/4