

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

DDB

1. Location of well: County SHERMAN		Fraction NW 1/4 SE 1/4 SE 1/4 SE 1/4		Section number 20		Township number T 8 S R 42 E W		Range number 42	
2. Distance and direction from nearest town or city: 1 E 1/4 N of KANORADO KANS				3. Owner of well: CHESTER CLAMER					
Street address of well location if in city:				R.R. or street:					
City, state, zip code: KANORADO, KANS. 67741				6. Bore hole dia. 7 1/4 in. Completion date 4-6-77					
4. Locate with "X" in section below: Sketch map:				Well depth 207 ft.					
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
5. Type and color of material				From		To		9. Casing: Material Steel Height: Above or below	
Clay Gravel & Sandstone				0		105		Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 3 1/2 in.	
Gravel				105		121		RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 16 lbs./ft.	
Sandstone & Clay				121		149		Dia. 8 in. to 97 ft. depth Wall Thickness: inches or	
Gravel				149		153		Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 119	
Clay Gravel & Sandstone				153		181		10. Screen: Manufacturer's name PORR	
Gravel				181		185		Type Mill salt Dia. 4 1/2	
Sandstone				185		192		Slot/gauze 1/32 Length 30	
Gravel				192		198		Set between 288 ft. and 217 ft.	
Sandstone				198		199		Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 to 1/2	
Sand				199		203		11. Static water level: 105 ft. below land surface Date 4-8-77	
Clay & Sandstone				203		216		12. Pumping level below land surfaces: 116 ft. after 6 hrs. pumping 8 g.p.m.	
Gravel				216		217		____ ft. after ____ hrs. pumping ____ g.p.m.	
Soapstone				217		231		Estimated maximum yield 8 g.p.m.	
Shale				231		235		13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date	
(Use a second sheet if needed)				235		235		14. Well head completion: NONE Pitless adapter _____ Inches above grade	
				235		235		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8" to 10 ft.	
18. Elevation:		19. Remarks: Concrete was Run By Farmer.							
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. FOUST SUPPLY CO INC 144 Business name License No. Address BOX 338 GOODLAND Signed Ralph Egan Date 5-6-77 Authorized representative							

T 8 S R 42 E W
 Sec 20
 NW 1/4 SE 1/4