

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County CLOUD	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 28	Township number T 8 S R 5 E (W)	
2. Distance and direction from nearest town or city:	1/2 S - 2 1/2 W		3. Owner of well:	WILLIAM E. TINKLER	
Street address of well location if in city:	GLASCO, KANS		R.R. or street:	RR #1	
			City, state, zip code:	GLASCO, KANS 67445	
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 8 in. Completion date 5/27/76	Well depth 140 ft.	
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock	
			9. Casing: Material PVC Height Above or below	Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 15 in.	
			RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft.	Dia. 5 in. to 140 ft. depth Wall Thickness: inches or	
			Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth	gauge No. 1214	
5. Type and color of material	From	To	10. Screen: Manufacturer's name PUMPIO		
TOPSOIL	0	2	Type PVC Dia. 5"		
BROWN CLAY	2	10	Slot/gauze 1/4" Length 20'		
SANDROCK	10	32	Set between 120 ft. and 140 ft.		
GRAY CLAY	32	58	Gravel pack? YES Size range of material 1/4 X 1/4		
RED CLAY	58	83	11. Static water level: 85 ft. below land surface Date 5/27/76		
SANDROCK w/CLAY LAYERS	83	90	12. Pumping level below land surfaces:		
SANDROCK	90	100	____ ft. after ____ hrs. pumping ____ g.p.m.		
GRAY CLAY	100	107	____ ft. after 1 hrs. pumping ____ g.p.m.		
SANDROCK	107	117	Estimated maximum yield 10 g.p.m.		
GRAY CLAY	117	123	13. Water sample submitted: ____ Yes <input checked="" type="checkbox"/> No Date ____		
SANDROCK	123	131	14. Well head completion: 15 inches above grade		
GRAY CLAY	131	136	15. Well grouted? YES		
RED CLAY	136	140	With: <input checked="" type="checkbox"/> Neat cement ____ Bentonite ____ Concrete		
STOP	140		Depth: From 0 ft. to 10 ft.		
(Use a second sheet if needed)			16. Nearest source of possible contamination: 200 ft. WEST Type LOTS		
			Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No		
			17. Pump: <input checked="" type="checkbox"/> Not installed		
			Manufacturer's name ____		
			Model number ____ HP ____ Volts ____		
			Length of drop pipe ____ ft. capacity ____ g.p.m.		
			Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
			<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
			<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 1362	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			Business name GEO LOPEZ SONS INC 258 License No. ____		
			Address CLIFTON KANSAS		
			Signed Dan Lopez Date 5/76		
			Authorized representative		

28
 5-10
 28
 1/4 1/4 1/4
 NE NE NW