

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Osborne	Fraction SW 1/4 SW 1/4	Section number 14	Township number T 9 S	Range number R 14 W E/W
2. Distance and direction from nearest town or city: 14 mi. N.W. of Natoma Street address of well location if in city:		3. Owner of well: Dewey Carlin R.R. or street: #1 City, state, zip code: Natoma, Kansas 67651			
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"><div style="text-align: center; margin-right: 10px;">N 1 Mile W 1 Mile S</div><div style="border: 1px solid black; padding: 5px; text-align: center;">NW NE SW SE X</div><div style="margin-left: 10px;">E</div></div>		Sketch map: Well is 75' Southeast of old dwelling-8' from old pulgged well			
5. Type and color of material		From	To	6. Bore hole dia. 1 1/2 in. Completion date 5/2/78 Well depth 45 ft.	
Black top soil		0	5	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Red Clay		5	10	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gray clay		10	20	9. Casing: Material PVC Height: Above or below Threaded 1 Welded 12 Surface 12 in. RMP PVC Weight 3 lbs./ft. Dia. 6 in. to 45 ft. depth Wall Thickness: inches or Dia. 6 in. to 45 ft. depth gage No. 250	
White Limestone		20	35	10. Screen: Manufacturer's name 1/8" slots with saw Type 6" Dia. 6" Slot/gauze 1/8" Length 9' Set between 31' ft. and 40' ft. ft. and 40' ft. Gravel pack? yes Size range of material 1/8-1/4 cma	
Good water gravel		35	40	11. Static water level: 22 ft. below land surface Date 5/1/78	
4' of black shale		40	45	12. Pumping level below land surfaces: 21 ft. after 4 hrs. pumping 8 g.p.m. 21 ft. after 4 hrs. pumping 8 g.p.m. Estimated maximum yield 30 g.p.m.	
				13. Water sample submitted: mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12" inches above grade	
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
				16. Nearest source of possible contamination: ft. none Direction none Type none Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name HP Volts 115 Model number 115 HP 115 Volts 115 Length of drop pipe 115 ft. capacity 115 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Well bailed 30 gals per minute with 20' of water in hole. Owner agrees to run curb on well to States specification.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Oscar Rush Water Well 310 Business name Natoma, Kansas License No. 310 Address Natoma, Kansas Signed Oscar Rush Date 5/5 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5