


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Osborne	Township name Victor	Fraction NW$\frac{1}{4}$-SE$\frac{1}{4}$-SE$\frac{1}{4}$	Section number 16	Town number 9	Range number 14
Distance and direction from nearest town or city: 13 miles N.E. of Natoma Street address of well location if in city:			3 Owner of well: Frabk and Paul Ruggels Address: Natoma, Kansas			
Locate with "X" in section below: N  W S 1 Mile			Sketch map:			4 Well depth: 73 ft. Date of completion 2/16/76 Well diameter 10 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top soil			0	6'	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
White Clay and limestone			6'	40'	7 Casing: Material PVD Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 in. Diam. _____ Weight _____ lbs./ft. _____ 73 in. to _____ ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 73 in. to _____ ft. depth	
Hard gray shale and rock			40'	60'	8 Screen: Manufacturer _____ Type _____ Dia. _____ Slot/size 1/16" Length 8' Set between 61 ft. and 53 ft. _____ Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4"	
Soft yellow rock			60'	63'	9 Static water level: 30 ft. below land surface Date 2/16	
Blue shale			63'	73'	10 Pumping level below land surfaces: 65 ft. after 4 hrs. pumping 4 1/2 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 4 1/2 g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 57 ft. to 2 ft.	
					14 Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation N.A.. Owner agrees to buile up grade and run burb to meet State standards Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Oscar Rush 310 Business name _____ License No. _____ Address Natoma, Kansas 67651 Signed Oscar Rush Date 2/16/76 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5