


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County ROCKS	Township name WEST PLAINVILLE	Fraction N 1/4 N 1/4 E 1/4	Section number 32	Town number 9 South	Range number 18 West
Distance and direction from nearest town or city: 2 Mile West of PLAINVILLE			3 Owner of well: Pete Meitler Address: PLAINVILLE, KANSAS 67663			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 50 ft. Date of completion 4/3/78 Well diameter 10 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			CLAY & SAND		0	32
QUICK SAND		32	35	7 Casing: Material _____ Height: above/below _____ Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 1/2 in. Weight _____ lbs./ft. _____ PLA Dia. 8 in. to 40 ft. depth Steel 5 1/2 in. to 50 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
COURSE SAND		35	36	8 Screen: Manufacturer ARMCO Type Metall Dia. 5 1/2 Slot/gauze 1/8 Dia. Length 9' Set between 41 ft. and 50 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material 3/4" clat		
CLAY		36	41	9 Static water level: 33 ft. below land surface Date APRIL 1 - 78		
SAND & GRAVEL		41	50	10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.		
(use a second sheet if needed)			11 Water sample submitted: MR. Meitler with SAND SAMPLE <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
			12 Well head completion: 14" <input checked="" type="checkbox"/> Pitless adapter 12" inches above grade			
			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.			
			14 Nearest source of possible contamination: None within 1/2 mile ft. _____ Direction _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			16 Remarks: elevation			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JAMES BRIS WATER WELL 285 Business name License No. Address PLAINVILLE ROCK RISE KS Signed James B. Bris Date 4/3/78 Authorized representative			