

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <b>Rooks</b>		Fraction <b>1/4 SE 1/4 NE 1/4</b>		Section number <b>34</b>		Township number <b>9 S R 18</b>		Range number <b>18</b>	
2. Distance and direction from nearest town or city: <b>S.W. 1 1/4 Miles</b>				3. Owner of well: <b>Ned Colburn</b>					
Street address of well location if in city: <b>1109 S.W. 9th</b>				R.R. or street: <b>1109 S.W. 9th</b>					
4. Locate with "X" in section below:				Sketch map:					
				<p>6. Bore hole dia. <b>8 1/2</b> in. Completion date <b>8-9-10-77</b> Well depth <b>85</b> ft.</p> <p>7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other</p> <p>9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/></p> <p>10. Screen: Manufacturer's name <b>No casing run</b> Type <input type="checkbox"/> Dia. <input type="checkbox"/> Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>Medium</b></p> <p>11. Static water level <b>Test Hole #1</b> <b>6 7/8</b> ft. below land surface Date <b>4-5-77</b></p> <p>12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.</p> <p>13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/></p> <p>14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade</p> <p>15. Well grouted? <input checked="" type="checkbox"/> <b>Plugged</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>35</b> ft.</p> <p>16. Nearest source of possible contamination: ft. <b>50</b> Direction <b>East</b> Type <b>Lateral</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p>					
5. Type and color of material		Test Hole #1		From		To			
Alluvial		Test Hole #1		0		4			
Hard Brown Clay				4		33			
Fine Sand				33		60			
Brown Clay				60		84			
Shale				84		85			
<p>Test #1 by the Garage was cleaned out at the top 1'-15". To reach bottom we had to use a smaller auger to clean obstructing objects in the hole. We then washed chlorinated gravel pack from bottom to 35', then neat cement from 35' to land surface.</p>									
(Use a second sheet if needed)									
18. Elevation:		19. Remarks: <b>Witnesses</b> <b>Bram Gross</b> <b>Ken Zimmerman</b> <b>Jerry Gordon</b>				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Water Well Sales 280B</b> Business name <b>East 8th</b> License No. <input type="checkbox"/> Address <b>East 8th</b> Signed <b>Jerry Gordon</b> Date <b>8-30-77</b> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5