

L4

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | | |
|--|--|---|--------------------------------------|---|---------------------------------|-------------------------------|
| 1. Location of well: | | County BOOKS | Fraction 1/4 SE 1/4 NW 1/4 | Section number 35 | Township number T 9 S | Range number R 18 E |
| 2. Distance and direction from nearest town or city: Street address of well location if in city: 609 S. Broadway | | | | 3. Owner of well: Lowell Moore R.R. or street: 609 S. Broadway City, state, zip code: P. Leimville, KS | | |
| 4. Locate with "X" in section below: | | Sketch map: N Fence X Well Street moore Home | | 6. Bore hole dia. 2 1/2 in. Completion date 4-5 Well depth 10 ft. | | |
| | | | | 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary | | |
| 5. Type and color of material | | From | To | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | |
| Alluvial cover | | 0 | 3 | 9. Casing: Material Plastic Height: 0 above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 1/4 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 190 lbs./ft. Dia. 6 1/2 in. to 60 ft. depth Wall Thickness: inches or Dia. in. to in. ft. depth gage No. 258 | | |
| Hard brown clay | | 3 | 26 | 10. Screen: Manufacturer's name Conta Type PVC Dia. 5 1/2 Slot/gauge 5/32 Length 20 1/2 Set between 60 ft. and 40 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material Medium | | |
| White soft clay | | 26 | 42 | 11. Static water level: 40 ft. below land surface Date 4-7-77 mo./day/yr. | | |
| Sand - Medium water bearing | | 42 | 58 | 12. Pumping level below land surfaces: 43 ft. after 1 hrs. pumping 18 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 30 g.p.m. | | |
| Blue shale | | 58 | 60 | 13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date | | |
| <p>Well inspected by Dwight Brinkley in July 1977. Casing Height & Vent & Wiring corrected on Aug. 12, 1977. Witnesses Mrs. Lowell Moore Kenneth Zimmerman Brian Gross</p> | | | | 14. Well head completion: 12" Stopped away <input type="checkbox"/> Pitless adapter <input type="checkbox"/> _____ inches above grade | | |
| | | | | 15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. | | |
| | | | | 16. Nearest source of possible contamination: ft. 200 Direction south Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| | | | | 17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Unitel Pump Model number 3031 HP 1/3 Volts 230 Length of drop pipe 35 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| 18. Elevation: | | (Use a second sheet if needed) | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief: Water Well Sales 2808 Business name Kant 8th License No. Address Kant 8th Signed Jonny Gordon Date 8-9-77 Authorized representative | | |
| 19. Remarks: Well disinfected again on 8-9-77. Well raised up. Well seal & vent with conduit installed on Aug. 12, 1977 | | | | | | |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5