

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County <b>Rooks</b>	Fraction <b>SE 1/4 <del>SW</del> 1/4 NW/4</b>	Section number <b>35</b>	Township number <b>T 9 S R 18 E 10</b>	Range number
2. Distance and direction from nearest town or city: <b>Plainville City</b>			3. Owner of well: <b>Steven Blecha</b>			
Street address of well location if in city: <b>Plainville, Ks.</b>			R.R. or street: <b>200 S. Section Line</b>			
			City, state, zip code: <b>Plainville, Ks. 67663</b>			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>8</u> in. Completion date <b>12/30/78</b>	
					Well depth <u>59</u> ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <u>pvc</u> Height: Above or below Threaded <input type="checkbox"/> Welded <u>g1</u> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2.08</u> lbs./ft. Dia. <u>4</u> in. to <u>39</u> ft. depth Wall Thickness: inches or Dia. <u>4</u> in. to <u>39</u> ft. depth gage No. <u>0.237</u>	
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>MPI</u>		
Soil		0	1	Type <u>PVC</u> Dia. <u>4"</u>		
Yellow clay		1	15	Slot/gauze <u>1/16</u> Length <u>20'</u>		
White sand rock with some clay		15	22	Set between <u>39'</u> ft. and <u>59</u> ft.		
Brown clay		22	25	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8-3/16</u>		
fine <del>clay</del> sand		25	30	11. Static water level: <u>12/30/78</u> /day/yr. <u>30.6</u> ft. below land surface Date		
Brown clay stringers		30	32	12. Pumping level below land surfaces: <u>32'6"</u> after <u>1</u> hrs. pumping <u>20</u> g.p.m. <u>32'6"</u> after <u>1</u> hrs. pumping <u>20</u> g.p.m. Estimated maximum yield <u>280</u> g.p.m.		
Fine to medium sand		32	49	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Brown clay		49	51	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> inches above grade		
White hard clay with river sand embedded		51	70	15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Brown clay		70	91	16. Nearest source of possible contamination: ft. <u>30'</u> Direction <u>south</u> Type <u>sewerline</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Blue shale		91	96	17. Pump: Not installed Manufacturer's name <u>Pumpco</u> Model number _____ HP <u>1/2</u> Volts <u>230</u> Length of drop pipe <u>56</u> ft. capacity <u>20</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>JRW Water Service 327</b> Business name License No. Address <u>Rt. 1, Box 27, Stockton, Ks</u> Signed <u>Wesley Jackson</u> Date <u>2-7-79</u> Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>Cement slab extends in excess of 5' in every direction from well esg.</u>				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5