

1 LOCATION OF WATER WELL County: <u>Sheridan</u>	Fraction <u>2 1/4 N/E</u> 1/4 N/E 1/4 <u>S/E</u> <del>1/4</del>	Section Number <u>27</u>	Township Number T <u>9</u> S	Range Number R <u>27</u> EW
---	--	-----------------------------	---------------------------------	--------------------------------

Distance and direction from nearest town or city? 7 east, 7 south, of Hoxie  
 Street address of well if located within city?

2 WATER WELL OWNER: Bill Fleming  
 RR#, St. Address, Box #: Rt. 2  
 City, State, ZIP Code: Hoxie, Kansas 67740  
 Board of Agriculture, Division of Water Resources  
 Application Number:


3 DEPTH OF COMPLETED WELL: ~~186~~ 192 ft. Bore Hole Diameter: 20 in. to 192 ft., and in. to ft.  
 Well Water to be used as:  
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well  
 2 ~~Residential~~ 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)  
 7 Lawn and garden only 10 Observation well  
 Well's static water level: 109 ft. below land surface measured on March month 25 day 1981 year  
 Pump Test Data: Well water was 180 ft. after 16 hours pumping 150 gpm  
 Est. Yield 150 gpm: Well water was ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED:  
 1 ~~Steel~~ 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped  
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded   
 7 Fiberglass Threaded  
 Blank casing dia: 12 in. to 112 ft., Dia in. to ft., Dia in. to ft.  
 Casing height above land surface: 48 in., weight 22 lbs./ft. Wall thickness or gauge No. 188  
 TYPE OF SCREEN OR PERFORATION MATERIAL:  
 1 ~~Steel~~ 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement  
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)  
 Screen or Perforation Openings Are:  
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)  
 2 Louvered shutter 4 ~~Key punched~~ 6 Wire wrapped 9 Drilled holes  
 7 Torch cut 10 Other (specify)  
 Screen-Perforation Dia: 12 in. to 80 ft., Dia in. to ft., Dia in. to ft.  
 Screen-Perforated Intervals: From 112 ft. to 192 ft., From ft. to ft.  
 Gravel Pack Intervals: From 10 ft. to 192 ft., From ft. to ft.

5 GROUT MATERIAL: ~~Steel casing~~ 2 Cement grout 3 Bentonite 4 Other  
 Grouted Intervals: From 2' Above level ft. to 10' ft., From ft. to ft., From ft. to ft.  
 What is the nearest source of possible contamination:  
 1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well  
 2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)  
 3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines none  
 Direction from well: How many feet? Water Well Disinfected? Yes No   
 Was a chemical/bacteriological sample submitted to Department? Yes No  If yes, date sample was submitted month day year: Pump Installed? Yes  No  
 If Yes: Pump Manufacturer's name: Goulds Model No. 6JLC HP 10 Volts 230  
 Depth of Pump Intake: 182 ft. Pumps Capacity rated at 180 gal./min.  
 Type of pump: 1 ~~Submersible~~ 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) ~~constructed~~ (2) reconstructed, or (3) plugged under my jurisdiction and was completed on March month 26 day 1981 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 144  
 This Water Well Record was completed on May month 15 day 1981 year under the business name of Foust Supply Co., Inc. by (signature) Ralph Elmer

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM		TO		LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	107	113	119	topsoil, clay, gravel		
	107	113	113	119	gravel			
	113	119	119	146	clay, sandstone			
	119	146	146	155	sand, gravel			
	146	155	155	160	clay, rock			
	155	160	160	166	sand			
	160	166	166	180	clay			
	166	180	180	183	sand			
	180	183	183	192	clay			
	183	192	192		shale			



ELEVATION:  
 Depth(s) Groundwater Encountered 1. 109 ft. 2. 119 ft. 3. 155 ft. 4. 166 ft. (Use a second sheet if needed)  
 INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

DP

OFFICE USE ONLY  
T  
R  
27  
END  
SEC  
27  
NE 1/4  
NE 1/4  
SE 1/4