


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

CAA

DATE Added 7-16-79
AL

1. Location of well:		County Sheridan	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 34	Township number T 9 S R 28	Range number 28
2. Distance and direction from nearest town or city: 8 1/2 South; 1/2 East Street address of well location if in city:			3. Owner of well: Tom Haffner R.R. or street: City, state, zip code: Grainfield, KS 67737			
4. Locate with "X" in section below: 			Sketch map:		6. Bore hole dia. 30 in. Completion date _____ Well depth 181 ft. 12-16-78	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input checked="" type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay & Layers of Gravel			0	80	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sand & Gravel			80	90	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.75 lbs./ft. Dia. 16 in. to 181 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .188	
Clay Sandy			90	127	10. Screen: Manufacturer's name Cook Type Wire Wrapped Dia. 16" Slot/gauze 100 Length 10 Set between 171 ft. and 181 ft. Perf-Bridgel and 171 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 x 5/8	
Coarse Sand & Gravel			127	138	11. Static water level: _____ mo./day/yr. 101 ft. below land surface Date 12-19-78	
Clay			138	146	12. Pumping level below land surfaces: 173 ft. after 2 hrs. pumping 798 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 798 g.p.m.	
Coarse Sand & Gravel			146	152	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Clay & Sand & Gravel Layers			152	165	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Coarse Sand & Gravel			165	178	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Ochre & Shale			178	185	16. Nearest source of possible contamination: ft. 6000 Direction NW Type Farmstead Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
(Use a second sheet if needed)					17. Pump: Not installed Manufacturer's name Floway Model number 10DOH HP 60 Volts _____ Length of drop pipe 179 ft. capacity 700 g.p.m. Type: <input checked="" type="checkbox"/> <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					18. Elevation:	
					19. Remarks:	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245 Business name Box 852 Colby, KS 67701 Address 67701 Signed [Signature] Date 7-16-79 Authorized representative	

T 9 R 28 S 34 NE NE SW 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5