

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ottawa	Fraction N 1/4 SE 1/4 NE 1/4	Section number 25	Township number T 9 S R 3 E/W	Range number 3
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:		
8 N. 6 E. 1/4 S. from Minneapolis, Mo.			Stanley Briggs 17A Minneapolis, Mo 67467		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 2 1/2 in. Completion date Well depth 174 ft. 6-7-77	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top soil		0	3	9. Casing: Material transite Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. No in. to 174 ft. depth; Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 7	
Clay		3	42	10. Screen: Manufacturer's name Johnson Type transite Dia. 1 1/2 Slot/gauze <input type="checkbox"/> Length 78 Set between 96 ft. and 174 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8	
Fine sand		42	46	11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 3-30-77	
Soft clay		46	61	12. Pumping level below land surfaces: 104 ft. after 2 hrs. pumping 400 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 600 g.p.m.	
Rusty sand & gravel		61	70	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 3-30-77	
Good clean white sand rock		70	109	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade	
Shale		109	112	15. Well grouted? <input checked="" type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Sand rock		112	115	16. Nearest source of possible contamination: ft. 100 Direction NE Type septic Well disinfected upon completion? HTH Yes <input type="checkbox"/> No <input type="checkbox"/>	
Shale		115	116	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Shale sand rock mixed		116	121	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz Bemis License No. 134 Business name Great Bend Mo. 67530 Address Great Bend Mo. 67530 Signed Stanley Briggs Date 8-26-77 Authorized representative	
Sand rock		121	134		
Shale		134	136		
Soft rock & pyrite		136	140		
Good clean sand rock		140	174		
Blue shale		174	175		
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 9 S R 3 E
Sec 25
1/4 1/4 1/4