


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

CSA CAC

1 Location of well:	County Sheridan	Township name Soloman	Fraction SW	Section number 3	Town number 9	Range number 30
Distance and direction from nearest town or city: Street address of well location if in city: 3 miles SW of Squin, KS.				3 Owner of well: Baalman & Sons Hoxie, KS Address:		
Locate with "X" in section below: N  W E S 1 Mile				4 Well depth: 227 ft. Date of completion 1-22-75 Well diameter 28 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
From To				7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. Weight 7 gauge 137 in. to 217 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 174 in. to 227 ft. depth		
				8 Screen: Manufacturer W. A. Brown Type Bridge Dia. 16" Slot/gauze 1/8 Length 2" Set between 137 ft. and 217 ft. Fittings: 10' of Cook - 217 to 227 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 x 5/8		
Clay & sand streaks				9 Static water level: 120 ft. below land surface Date 1-6-75		
Fine to coarse sand & gravel				10 Pumping level below land surfaces: 200 ft. after 2 hrs. pumping 600 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 600 g.p.m.		
Sandy clay				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
Fine to coarse sand & gravel				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 Inches above grade		
Sandy clay				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> & clay Depth: From 0 ft. to 10 ft.		
Cemented sand				14 Nearest source of possible contamination: ft 1 mile Direction East Type unknown Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Coarse gravel - loose				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Bryon Jackson Model number ____ HP 80 Volts ____ Length of drop pipe 210 ft. capacity 600 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Cemented sand				16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley 2935 (TOPO) 2945		
Fine to coarse sand & gravel & cemented streaks				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump Inc. 245 Business name License No. ____ Address P.O. Box 852, Colby, KS. Signed Roy E. Janice Date May 28-75 Authorized representative		
Cemented sand - hard						
Fine to coarse sand & gravel - loose						
Fine to coarse sand & gravel						
Shale						
(use a second sheet if needed)						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5