

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

AAC

1 Location of well:	County Sheridan	Township name Solomon	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 11	Town number 9	Range number 30W				
Distance and direction from nearest town or city: From Sequin, Ks 3 1/2 miles South 2 1/2 miles West			3 Owner of well: Baalman Farms							
Street address of well location if in city:			Address: Hoxie, Kansas							
Locate with "X" in section below:		Sketch map:		4 Well depth: 205 ft. Date of completion 1/17/76 Well diameter 30 in.						
N W ——— E S 1 Mile				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary						
2		Type and color of material		From		To		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
								7 Casing: Material Steel Height: above/below Threading: <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 115 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
		Soil, sand and clay		0		107		8 Screen: Brown: 10' Cook Manufacturer _____ Type Regular Dia. 16" Slot/gauze 10% Length 80' Set between 115 ft. and 195 ft. 205 Fittings: 1/4 X 5/8; 50% #1 Gravel pack <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material _____		
		Medium sand		107		118		9 Static water level: 102 ft. below land surface Date 1/19/76		
		Clay		118		124		10 Pumping level below land surfaces: 190 ft. after 2 hrs. pumping 907 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 907 g.p.m.		
		Cemented sand and clay		124		148		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
		Gravel		148		157		12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
		Clay		157		170		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> clay Depth: From 0 ft. to 10 ft.		
		Gravel		170		176		14 Nearest source of possible contamination: ft. 2000 Direction East Type Feedlot Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
		Sand stone and clay		176		190		15 Pump: <input type="checkbox"/> Not installed 9-27-76 Manufacturer's name Bryon Jackson Model number 7117 HP 75 Volts _____ Length of drop pipe 190 ft. capacity _____ g.p.m. Type: 8 stage 10" GH bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		Gravel		190		199		16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
		Yellow clay and shale		199		210		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well and Pump 245 Business name _____ License No. _____ Address PO Box 852 Colby, Ks. Signed Dale Berry Date 3-22-76 Authorized representative		
		BROCK 199'								

9 30W 11 SW NE NE