


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

B3B

1. Location of well:	County Thomas	Fraction NW 1/4 NW 1/4 NW 1/4	Section number X 30	Township number T X 9 S	Range number R XX 31 E/W
2. Distance and direction from nearest town or city: I-70 - 83 mi go 3 North; 2 East; 1 North Street address of well location in city:			3. Owner of well: Ken Schroeder R.R. or street: City, state, zip code: Oakley, Kansas		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 30 in. Completion date 10-4-76 Well depth 181 ft.
Clay			0	40	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Med. Gravel, Clay			40	80	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Coarse Sand, Med. Gravel, Clay Streaks			80	120	9. Casing: Material Steel Height: Above or below XXXX Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 16 in. to 91 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7
Med. Gravel, Sandstone			120	141	10. Screen: Manufacturer's name Brown Type Regular Dia. 16" Slot/gauze 10% Length 80' Set between 91 ft. and 171 ft. 10' Cook 171 ft. and 181 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8-30 #1
Ochre, Shale			141	181	11. Static water level: <input type="checkbox"/> mo./day/yr. 81 ft. below land surface Date 10-6-76
BROCK 141'					12. Pumping level below land surfaces: 176 ft. after 2 hrs. pumping 2084 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 2084 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> Clay With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 4000 Direction South Type House Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852, Colby, KS Signed Darryl Berry Date 11/16/76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5