

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Thomas	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 33	Township number T 9 S	Range number R 31 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 6 M. 1 W 1 M 1/2 W of Gempson			3. Owner of well: David Ostmeyer R.R. or street: City, state, zip code: Oakley, Kansas			
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: Pasture			6. Bore hole dia. 9 in. Completion date 5-18-80 Well depth 146 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
From To			9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 6 in. to _____ ft. depth Wall Thickness: inches or Dia. 6 in. to 146 ft. depth gage No. 200TH			
			10. Screen: Manufacturer's name Geos Lowell Type PVC Dia. 5" Slot/gauze 18 Length 8' Set between 158 ft. and 146 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 14-3/4			
Top soil S clay M. gravel S. clay M. gravel Sand stone M. gravel S clay F sand S clay M. gravel Other			11. Static water level: _____ mo./day/yr. 85 ft. below land surface Date 5-18-80			
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield No Test g.p.m.			
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. 75 Direction W Type Drum Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
(Use a second sheet if needed)			17. Pump: _____ Not installed Manufacturer's name AT Industrial Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. B+B Drilling 376 Business name _____ License No. _____ Address Guinnell, Ky Signed Joseph Beckman Date 6-16-80 Authorized representative			
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5