


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Thomas	Township name North Ranada	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 3	Town number 9	Range number 32
Distance and direction from nearest town or city: 9 miles East; 6 1/2 miles South Street address of well location if in city:				3 Owner of well: Clarence Cersovsky Address: Colby, Kansas 67701		
Locate with "X" in section below: 				4 Well depth: 157 ft. Date of completion 1/15/76 Well diameter 36 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Steel Height: above/below 14 ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 87 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
				8 Screen: Manufacturer Brown 10' Cook Type Regular Dia. 16" Slot/gauze 10% Length 60" Set between 87 ft. and 147 ft. 157 Fittings: 1/4 X 5/8; 50% #1 Gravel pack <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Size range of material _____		
				9 Static water level: 72' ft. below land surface Date 01-16-76		
				10 Pumping level below land surfaces: 155' ft. after 2 hrs. pumping 433 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 433 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: ft. 4000 Direction West Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway 2-9-76 Model number _____ HP 60 Volts _____ Length of drop pipe 150 ft. capacity _____ g.m.p. Type: 9 stage 10" DKL bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation BROCK 156 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well and Pump 245 Business name _____ License No. _____ Address PO Box 852 Colby, Ks Signed Dolly Perry Date 3/22/76 Authorized representative		