

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

COLBY SE

WATER WELL RECORD  
KSA 82a-1201-1215


T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Thomas</b>	Township name <b>Summers</b>	Fraction <b>SE 1/4</b>	Center	Section number <b>#8</b>	Town number <b>T 9 S</b>	Range number <b>R 33 W</b>
---------------------	-------------------------	---------------------------------	---------------------------	--------	-----------------------------	-----------------------------	-------------------------------

Distance and direction from nearest town or city: **3 3/4 Mile West & 1/2 mile North of Mingo, Kansas**  
Street address of well location if in city: \_\_\_\_\_  
3 Owner of well: **Glen W. Schiffner Estate**  
Address: **Colby, Kansas 67701**

Locate with "X" in section below:



Sketch map:

4 Well depth: **263** ft. Date of completion **1-27-75**  
Well diameter **17** in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug  
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry  
☒ Irrigation ☐ Air conditioning ☐ Commercial  
☐ Test well ☐ \_\_\_\_\_

7 Casing: Material **concrete** Weight: above/below  
Threaded ☐ Welded ☐ Surface **12** in.  
Diam. **17** in. to **263** ft. depth! Drive shoe? ☐ Yes ☒ No  
\_\_\_\_\_ in. to \_\_\_\_\_ ft. depth!

2	Type and color of material	From	To
	Soil	0	5
	Clay & sand streaks	5	118
	Fine to coarse sand & gravel	118	124
	Sandy clay & fine to coarse sand & gravel	124	137
	Fine to coarse sand & gravel	137	160
	Sandy clay	160	169
	Cemented sand & clay	169	174
	Fine to coarse sand & gravel	174	199
	Sandy clay	199	201
	Fine to coarse sand & gravel	201	205
	Sandy clay	205	210
	Sandy clay & gravel streaks	210	219
	Fine to coarse sand & gravel & clay lenses	219	253
	Fine to coarse sand & gravel	253	263
	Shale	263	
	<b>BROCK 263'</b> (use a second sheet if needed)		

8 Screen: **Kelly Well Co.**  
Manufacturer **Kelly Well Co.**  
Type \_\_\_\_\_ Dia. **17"**  
Slot/gauze **1/4** Length **6"**  
Set between **193** ft. and **263** ft. \_\_\_\_\_  
Fittings:  
Gravel pack ☒ Yes ☐ No Size range of material **1/8x5/8**

9 Static water level:  
**115** ft. below land surface Date **1-27-75**  
10 Pumping level below land surfaces:  
**241** ft. after **2** hrs. pumping **990** g.p.m.  
\_\_\_\_\_ ft. after \_\_\_\_\_ hrs. pumping \_\_\_\_\_ g.p.m.  
Estimated maximum yield **990** g.p.m.

11 Water sample submitted:  
☐ Yes ☒ No Date \_\_\_\_\_

12 Well head completion:  
☐ Pitless adapter **12** inches above grade

13 Well grouted? ☒ Yes ☐ No  
☐ Neat cement ☒ Bentonite ☐ & clay  
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination:  
ft. **3/4 mile** Direction **S.W.** Type **septic tank**  
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump: ☐ Not installed  
Manufacturer's name **Johnston**  
Model number **PG16675** HP **100** Volts \_\_\_\_\_  
Length of drop pipe **240** ft. capacity **650** g.m.p.  
Type:  
☐ Submersible ☒ Turbine  
☐ Jet ☐ Reciprocating  
☐ Centrifugal ☐ Other

16 Remarks: elevation

Topography:

☐ Hill  
☐ Slope  
☒ Upland  
☐ Valley

17 Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
**Western Well & Pump Inc.**  
Business name **P.O. Box 852** License No. **245**  
Address \_\_\_\_\_  
Signed **Roy E. Jensen** Date **2-16-75**  
Authorized representative