


WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BCC

1. Location of well: County Thomas		Fraction SW 1/4 NW 1/4 NW 1/4	Section number 15	Township number T 9 S R 33	Range number 33
2. Distance and direction from nearest town or city: Mingo; 2W; 1/4S			3. Owner of well: Abe Friesen		
Street address of well location if in city:			R.R. or street:		
			City, state, zip code: Colby, Kansas		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 36 in. Completion date 11-10-		
<div style="text-align: center;">N 1 Mile W E S 1 Mile</div> 			Well depth 260 ft.		
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
			9. Casing: Material Steel Height: Above or below XXX Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 16 in. to 170 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7		
Type and color of material			10. Screen: Manufacturer's name Brown		
			Type Bridge Dia. 16" Slot/gauze 10% Length 80' Set between 170 ft. and 250 ft. 10' Cook ft. and 260 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 5/8		
From To			11. Static water level: mo./day/yr. 170 ft. below land surface Date 1-11-77		
			12. Pumping level below land surfaces: 256 ft. after 2 hrs. pumping 681 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 681 g.p.m.		
Clay, Gravel			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: Pitless adapter 12 inches above grade		
Clay, Fine Sand			15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 2000' Direction NE Type House Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
Fine to Coarse Sand			17. Pump: Not installed Manufacturer's name Customers Pump Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: Submersible Turbine Jet Reciprocating Centrifugal Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852 Colby, KS 67701 Signed Ann Hustner Date 1/23/77 Authorized representative		
18. Elevation:			19. Remarks:		
Topography: Hill Slope <input checked="" type="checkbox"/> Upland Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023