


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Thomas	Fraction Center 1/4 1/4 NE 1/4	Section number 16	Township number T 9 S	Range number R 33 E/W
2. Distance and direction from nearest town or city: From Colby; 7 South; 2 3/4 East; 1/4 South Street address of well location if in city:			3. Owner of well: Abe Freisen R.R. or street: City, state, zip code: Mingo, Kansas		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 36 in. Completion date 8-4-76 Well depth 255 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 16 in. to 165 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7		
			10. Screen: Manufacturer's name Brown Type Regular Dia. 16" Slot/gauze 10% Length 80' Set between 165 ft. and 245 ft. 10' Cook 245 ft. and 255 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2x5/8 50% #1		
Med. Gravel, Sandy Clay Layers			From	To	11. Static water level: <input type="checkbox"/> mo./day/yr. 120 ft. below land surface Date 8-5-76
Sandy Clay, Sand Stone Layers			0	100	12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. 246 ft. after 2 hrs. pumping 744 g.p.m. Estimated maximum yield 744 g.p.m.
Med. Gravel, Sandy Clay Layers			100	111	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
Sandy Clay, Sand Stone Layers			111	150	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
Med. Gravel, Sandy Clay Layers			150	163	15. Well grouted? <input checked="" type="checkbox"/> Clay With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 10 ft.
Sandy Clay, Sand Stone Layers			163	170	16. Nearest source of possible contamination: ft. 1 M Direction N Type Farmstead Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Med. Gravel & Sandy Clay Layers			170	190	17. Pump: Manufacturer's name Floway Not installed Model number 056105 HP 100 Volts 480 Length of drop pipe 240 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Fine Sandx, Sandy Clay Layers			190	203	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name License No. Address Box 852, Colby, KS 67701 Signed Sally Berry Date 9-22 Authorized representative
Sandy Clay, Sand Stone Layers			203	215	
Fine Sand Tite Sandy Clay Layers			215	235	
Med. Gravel			235	250	
Ochre & Shale			250	255	
BROCK 250					
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5