


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

OAKLEY NW

WATER WELL RECORD
KSA 82a-1201-1215

CBB CCB

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Thomas	Fraction NW 1/4 NW 1/4 SW 1/4	Section number #26	Township number T 9 S R 33	Range number X W
2. Distance and direction from nearest town or city: 2 1/2 Miles South & one mile west Street address of well location if in city:		3. Owner of well: John Hansen R.R. or street: Mingo, Kansas City, state, zip code:			
4. Locate with "X" in section below: Sketch map: 		6. Bore hole dia. 30 in. Completion date 10-10-75 Well depth 284 ft.			
5. Type and color of material		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Clay		9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight .188 lbs./ft. Dia. 16 in. to 170 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7			
		10. Screen: Manufacturer's name W. A. Brown Type regular Dia. 16 " Slot/gauze 10% Length 100 ' Set between 170 ' ft. and 274 ' ft. 10' of cook ft. and 284 ' ft. Gravel pack <input checked="" type="checkbox"/> yes Size range of material: 1/4 x 5/8			
Gravel		11. Static water level: 143 ft. below land surface Date 10-14-75			
Clay		12. Pumping level below land surfaces: 280 ft. after 2 hrs. pumping 600 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 600 g.p.m.			
Coarse sand & gravel		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
Clay & sand streaks		14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
Coarse sand & gravel		15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
Clay & sand streaks		16. Nearest source of possible contamination: ft. 1500 Direction S.W. Type farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Clay & cement streaks		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number <input type="checkbox"/> HP 100 Volts <input type="checkbox"/> Length of drop pipe 283 ft. capacity 550 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Fine to medium sand & cement streaks & clay layers		18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			
Medium sand & clay streaks		19. Remarks: 3150 (TOPO) 3142 BROCK 280 (Use a second sheet if needed)			
Fine to medium sand		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc. 245 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address P.O. Box 852, Colby, Ks. Signed Roy Hansen Date 10-14-75 Authorized representative			
Medium sand & clay streaks					
Fine to medium sand					
Cement					
Medium to coarse sand & sand stone streaks					
Coarse sand & gravel					
Sand stone					
Medium to coarse sand & gravel					
Shale					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5