

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


WINONA NE

WATER WELL RECORD
KSA 82a-1201-1215

DRB

9 33 W 31 NW SE
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Thomas	Township name Summers	Fraction NNNW SE 1/4	Section number #31	Town number T 9 S	Range number R 33 W
Distance and direction from nearest town or city: 11 1/2 miles South & 3/4 miles East of Colby, Ks.				3 Owner of well: Virgil Buller Address: Colby, Kansas 67701		
Locate with "X" in section below: 				4 Well depth: 256 ft. Date of completion 7-22-75 Well diameter 36 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Top Soil				7 Casing: Material steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. = Diam. 0 in. to 186 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
Clay & sand streaks				8 Screen: Manufacturer W. A. Brown Type bridge Dia. 16" Slot/gauze 1/8 Length 2" Set between 186 ft. and 246 ft. Fittings: 10' cook = 256 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 x 5/8		
Coarse sand & gravel				9 Static water level: 180' ft. below land surface Date 7-24-75		
Sand stone & sandy clay				10 Pumping level below land surfaces: 245 ft. after 2 hrs. pumping 525 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 525 g.p.m.		
Medium to coarse sand				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Sandy clay				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Fine to coarse sand				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> & clay Depth: From 0 ft. to 10 ft.		
Clay				14 Nearest source of possible contamination: ft. 3,000 Direction Southwest Homestead Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Fine to coarse sand & clay & sandstone				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Byron Jackson Model number 100 HP _____ Volts _____ Length of drop pipe 245 ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sandy clay				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump, Inc 245 Business name _____ License No. _____ Address P.O. Box 852, Colby, Ks Signed Roy E. Jensen Date 7-23-75 Authorized representative		
Fine to medium sand & sandstone streaks						
Fine to medium sand & clay						
Medium to coarse sand & gravel						
Shale						
BROCK 252'						
(use a second sheet if needed)						
16 Remarks: elevation 3188 (TOPO) Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5