


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

TWP: Summers

ABD

1. Location of well:	County Thomas	Fraction SE 1/4 NW 1/4 NE 1/4	Section number 34	Township number T 9 S	Range number R 33 E/W
2. Distance and direction from nearest town or city: From Colby 12 miles South 3 3/4 East & 1/4 mi. South Street address of well location if in city:			3. Owner of well: Harold Herbel R.R. or street: City, state, zip code: Colby, Kansas		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 36 in. Completion date 2/24/76 Well depth 295 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 18.5 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
			10. Screen: Manufacturer's name Brown 10" Cook Type Regular Dia. 16" Slot/gauze 10% Length 100' Set between 185 ft. and 285 ft. 285 ft. and 295 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 70% #1 30% 1/4 X 5		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 140 ft. below land surface Date 2/25/76		
			12. Pumping level below land surfaces: 280 ft. after 2 hrs. pumping 979 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 979 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 2600 Direction NE Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number 7614 HP 100 Volts Length of drop pipe 280 ft. capacity 550 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks: BROCK 292'		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name PO Box 852 Colby, KS. License No. Address Signed _____ Date _____ Authorized representative		