

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

REPLACEMENT WELL

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Thomas	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 36	Township number T 9 S	Range number R 33 W
2. Distance and direction from nearest town or city: Mingo, KS 3 3/4 South; 1/4 East Street address of well location if in city:			3. Owner of well: Delton Hubert R.R. or street: P. O. Box 647 City, state, zip code: Monument, Kansas 67747		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 36 in. Completion date 7-13-76 Well depth 270 ft.
Top Soil			0	45	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Coarse Sand and Gravel			45	89	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>
Clay			89	111	9. Casing: Material Steel Height: Above or Below <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 16 in. to 160 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. #7
Coarse Sand and Gravel			111	129	10. Screen: Manufacturer's name Brown Type Regular Dia. 16" Slot/gauze 10% Length 100' Set between 160' ft. and 260' ft. 10' Cook 260' ft. and 270' ft.
Clay			129	134	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 x 5/8 50% #1
Coarse Sand and Gravel			134	159	11. Static water level: 140 ft. below land surface Date 7-9-76 mo./day/yr.
Clay			159	167	12. Pumping level below land surfaces: 220 ft. after 2 hrs. pumping 750 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 750 g.p.m.
Coarse Sand and Gravel			167	199	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.
Clay and Mix Sand			199	218	14. Well head completion: 12 Inches above grade Pitless adapter <input type="checkbox"/>
Coarse Sand and Gravel			218	224	15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 10 ft.
Sand Stone			224	225	16. Nearest source of possible contamination: ft. 2600' Direction NNW Type Farm
Clay			225	237	Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Med. Sand			237	250	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Used Johnston Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m.
Clay			250	254	Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Reciprocating <input type="checkbox"/> Other <input type="checkbox"/>
Sandy Clay			254	263	<input type="checkbox"/> Jet <input type="checkbox"/> Centrifugal
Coarse Sand and Gravel			263	270	
Shale (Use a second sheet if needed)			270	280	
18. Elevation:	19. Remarks: BROCK 270'		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well & Pump 245 Business name Box 852 Colby, KS 67701 License No. 9-1576 Address Daily Pump Date 9-15-76 Signed Daily Pump Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5