


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Township - Summers

1. Location of well:		County Thomas	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 5	Township number T 9 S R 34 E	Range number 4W
2. Distance and direction from nearest town or city: From Colby, Ks 5 1/2 miles South; 4 1/2 miles West Street address of well location if in city:				3. Owner of well: William Keck R.R. or street: City, state, zip code: Colby, Kansas 67701		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date _____ Well depth 266 ft. 1/24/76		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	10	9. Casing: Material Steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 17 1/2 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 0.188		
Clay		10	73	10. Screen: Manufacturer's name Brown 10" Cook		
Medium to coarse sand & clay streaks		73	85	Type Regular Dia. 16" Slot/gauze 10% Length 80' Set between 176 ft. and 256 ft. 256 ft. and 266 ft.		
Sandy clay		85	114	Gravel pack? <input checked="" type="checkbox"/> Size range of material 5/8:50% #1		
Coarse sand & gravel		114	124	11. Static water level: 174 ft. below land surface Date 1/27/76 mo./day/yr.		
Clay		124	132	12. Pumping level below land surfaces: 250 ft. after 2 hrs. pumping 1515 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1515 g.p.m.		
Coarse sand & gravel		132	143	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay		143	146	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Coarse sand & gravel		146	155	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Depth: From 0 ft. to 10 ft.		
Sandy clay		155	163	16. Nearest source of possible contamination: ft. 2800 Direction NW Type Farm		
Coarse sand & gravel		163	167	Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
Cement		167	168	17. Pump: _____ Not installed 3/3/76		
Coarse sand & gravel		168	184	Manufacturer's name Bryon Jackson Model number 7118 HP 150 Volts _____ Length of drop pipe 250 ft. capacity 1000 g.p.m. Type: 7 stage 12" GH bowl <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Cement-hard		184	186	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Western Well and Pump 245 Business name _____ License No. _____ Address PO Box 852 Colby, Ks. Signed Sally Penny Date 3/22/76 Authorized representative		
Coarse sand & gravel		186	198			
Clay		198	213			
Coarse sand & gravel & clay streaks		213	228			
Medium to coarse sand		228	242			
Coarse sand & gravel		242	264			
Ochre & Shale		264	280			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5